



## Tar removal from low-temperature gasifiers

Zwart, Robil; van der Heijden, Simon; Emmen, Rob; Dall Bentzen, Jens; Ahrenfeldt, Jesper; Stoholm, Pder; Krogh, Jørn

*Publication date:*  
2010

*Document Version*  
Publisher's PDF, also known as Version of record

[Link back to DTU Orbit](#)

*Citation (APA):*  
Zwart, R., van der Heijden, S., Emmen, R., Dall Bentzen, J., Ahrenfeldt, J., Stoholm, P., & Krogh, J. (2010). *Tar removal from low-temperature gasifiers*. Energy Research Centre of the Netherlands (ECN). ECN-E-10-008 <http://www.ecn.nl/docs/library/report/2010/e10008.pdf>

---

### General rights

Copyright and moral rights for the publications made accessible in the public portal are retained by the authors and/or other copyright owners and it is a condition of accessing publications that users recognise and abide by the legal requirements associated with these rights.

- Users may download and print one copy of any publication from the public portal for the purpose of private study or research.
- You may not further distribute the material or use it for any profit-making activity or commercial gain
- You may freely distribute the URL identifying the publication in the public portal

If you believe that this document breaches copyright please contact us providing details, and we will remove access to the work immediately and investigate your claim.

# **Tar removal from low-temperature gasifiers**

**Robin Zwart (ECN)**

**Simon van der Heijden & Rob Emmen (Dahlman)**

**Jens Dall Bentzen (Dall Energy)**

**Jesper Ahrenfeldt (Risø DTU)**

**Peder Stoholm (DFBT)**

**Jørn Krogh (Anhydro)**



## Acknowledgement/Preface

This report is prepared within the framework of the ERA-NET Bioenergy project “Tar removal from low-temperature gasifiers”. The project was carried out by ECN and Dahlman from the Netherlands and Dall Energy, Risø DTU, DFBT and Anhydro from Denmark. Gratitude goes to the ERA-NET Bioenergy consortium and in particular SenterNovem and Energinet.dk for supporting this project. SenterNovem became part of Agentschap NL at the beginning of 2010 and is an agency of the Dutch Ministry of Economic Affairs and coordinates the so-called Energy Research Strategy (EOS) program out of which this project was partially financed. The Danish transmission system operator Energinet.dk is an authority under the Danish Ministry of Climate and Energy. Energinet.dk administers the Public Service Obligation Programme (PSO) in terms of the Forskel and the ForskVE programmes.

## Abstract

Biomass is considered an important source of renewable energy needed to realise national and European renewable energy goals and goals for CO<sub>2</sub> reduction. Biomass gasification as a technology is recognized generally as highly desirable because of its high efficiency towards all kind of energy products. Biomass can be gasified using many different technologies ranging from high-temperature processes as high as 1500°C to low-temperature processes as low as 500°C. The project “tar removal from low-temperature gasifiers” focuses at gasification processes below 800°C. These so-called low-temperature biomass gasification processes have certain advantages, i.e. they are suitable for fuels with low ash melting points, have a high cold gas efficiency and low tar dew point, require easier gas cooling and cleaning, provide longer residence times, and are associated with less heat transfer limitations within gasifier compared to gasifiers operated at 800 to 900°C.

For some applications the main disadvantage of low-temperature gasification is the relatively high tar level in the gas. This is why these processes generally are not considered being suitable for connection to gas engines, gas turbines, fuel cells or catalytic synthesis reactors. All the advantages mentioned above however, urge researchers to develop gas cleaning systems that can extend the application of low-temperature gasifiers from simple co-firing to also the mentioned applications. Being able to handle tars in the 700-800°C interval would be very attractive. This temperature is high enough to have limited tar yield and low enough to have an acceptable tar dew point.

In the project, two gas cleaning technologies are adapted and tested in connection to low-temperature gasification, i.e. (i) the OLGA tar removal technology developed by the Dutch partners in the project and (ii) the cooling, filtration and partial oxidation developed by the Danish partners in the project. The project aims at judging technical and economical suitability of these up-scalable tar removal methods connected to high-efficiency low-temperature gasification. Suitability opens the way to high efficient and high fuel flexible biomass gasification systems for the connection to gas engines, gas turbines, fuel cells or catalytic synthesis gas reactors.

It is concluded that lowering the gasification temperature will require some modifications of the OLGA technology, though it is expected OLGA can remove also tars from the product gas of a gasifier operated at temperatures below 650°C to low enough levels that a gas engine should run, based on tars. For dust removal, bag house filters are suitable when operated above the tar dew point of the gas. If this would require too high temperatures technically or economically feasible for filters, the OLGA could be applied in which dust can be removed at a temperature below the original tar dew point of the gas. The cooling of gasification is a challenge as long as dust and tars result in fouling in shell and tube heat exchangers. To overcome such problems so called “evaporative coolers” can be used where the evaporative energy of water (or some other liquid) is used to cool the gas.

# Contents

List of tables	5
List of figures	5
Summary	7
1. Introduction	11
1.1 Background	11
1.2 Problem definition	11
1.3 Objective	11
1.4 Approach	12
1.5 Reading instructions	12
2. Low-temperature gasification	13
2.1 Indirect air/steam-blown MILENA gasification	13
2.1.1 Description of MILENA	13
2.1.2 Applied operating conditions	14
2.1.3 Experimental results	15
2.2 Direct air-blown WOB gasification	18
2.2.1 Description of WOB	18
2.2.2 Applied operating conditions	18
2.2.3 Experimental results	19
2.3 Direct air-blown LT-CFB gasification	22
2.3.1 Applied operating conditions	24
2.3.2 Experimental results	25
3. Oil based gas washing (OLGA)	29
3.1 Description of OLGA	29
3.2 Required modifications for low-temperature gasification	31
3.2.1 The cooling section: the gas cooler and OLGA collector	31
3.2.2 The oil handling: the oil recovery system (ORS)	32
3.2.3 The tar removal: the OLGA absorber and stripper	33
3.3 Experimental results	34
3.3.1 OLGA micro scale	34
3.3.2 OLGA lab scale	35
3.3.3 OLGA pilot scale	37
3.3.4 ORS lab scale	38
3.3.5 ORS pilot scale	39
3.4 Integration of OLGA and LT-CFB	41
3.4.1 Available process input data	41
3.4.2 Theoretical process design	43
3.4.3 Remarks on the design	45
4. Filtration and partial oxidation	47
4.1 Purpose and Background	47
4.1.1 Bag House Filtration	47
4.1.2 Partial Oxidation	47
4.2 Description of the filtration and partial oxidation set-up	49
4.2.1 Gas cooling prior to bag house filtration	49
4.2.2 Bag House Filtration	51
4.2.3 Partial Oxidation	52
4.3 Experimental results	55
4.3.1 Gas Cooling	55
4.3.2 Filtration	56
4.3.3 Partial Oxidation	57

5.	System assessment	61
5.1	MILENA-OLGA based combined heat & power system	61
5.2	LT-CFB with gas cooling and cleaning	62
5.3	Implementation barriers	63
	5.3.1 General bioenergy barriers	64
	5.3.2 Specific barriers to gasification and gas cleaning	65
6.	Conclusions and recommendations	67
	Abbreviations and definitions	69
	References	71

## List of tables

Table 2.1	<i>MILENA lab scale gas composition</i> .....	15
Table 2.2	<i>MILENA lab scale tar concentration normalised to 0% N<sub>2</sub></i> .....	16
Table 2.3	<i>WOB lab scale operating conditions</i> .....	19
Table 2.4	<i>WOB lab scale main gas composition for beech wood / PE</i> .....	20
Table 2.5	<i>WOB lab scale ash composition for beech wood / PE</i> .....	21
Table 2.6	<i>All of the present 8 test with the new 100 kW<sub>th</sub> LT-CFB plant</i> .....	24
Table 2.7	<i>Data for fuels use in 100 kW LT-CFB tests nos. 3-8</i> .....	24
Table 3.1	<i>LT-CFB 100 kW<sub>th</sub> feedstock data</i> .....	41
Table 3.2	<i>LT-CFB 100 kW<sub>th</sub> fuel composition</i> .....	41
Table 3.3	<i>LT-CFB 100 kW<sub>th</sub> raw product gas composition (outlet gasifier)</i> .....	41
Table 3.4	<i>LT-CFB 100 kW<sub>th</sub> stripper / gasifier air or steam</i> .....	41
Table 3.5	<i>LT-CFB 100 kW<sub>th</sub> product gas at inlet OLGA</i> .....	42
Table 3.6	<i>LT-CFB 100 kW<sub>th</sub> solid particles at inlet OLGA</i> .....	42
Table 3.7	<i>LT-CFB 100 kW<sub>th</sub> tar data (simplified) at inlet OLGA</i> .....	42
Table 3.8	<i>LT-CFB 100 kW<sub>th</sub> tar data (composition) at inlet OLGA</i> .....	42
Table 3.9	<i>LT-CFB 100 kW<sub>th</sub> inorganic impurities data at inlet OLGA</i> .....	42
Table 3.10	<i>LT-CFB 100 kW<sub>th</sub> gas flow ranges</i> .....	43
Table 3.11	<i>LT-CFB 100 kW<sub>th</sub> water dew point gas</i> .....	44
Table 5.1	<i>MILENA 10 MW<sub>th</sub> design parameters</i> .....	61

## List of figures

Figure 1.1	<i>Scope of project</i> .....	12
Figure 1.2	<i>Effect of temperature on tar yield &amp; dew point</i> .....	12
Figure 2.1	<i>MILENA scheme</i> .....	14
Figure 2.2	<i>MILENA lab &amp; pilot facility</i> .....	14
Figure 2.3	<i>MILENA lab scale tar composition for beech wood &amp; sand</i> .....	16
Figure 2.4	<i>MILENA lab scale tar composition for beech wood &amp; olivine</i> .....	16
Figure 2.5	<i>MILENA pilot scale tar composition for clean wood pellets &amp; olivine (air on riser)</i> .....	17
Figure 2.6	<i>Relation between tar dew point and concentration</i> .....	17
Figure 2.7	<i>WOB scheme</i> .....	18
Figure 2.8	<i>WOB lab facility with HGF</i> .....	18
Figure 2.9	<i>WOB lab scale tar composition for RDF and for beech wood / PE (bulk)</i> .....	19
Figure 2.10	<i>WOB lab scale tar composition for RDF and for beech wood / PE (detailed)</i> .....	19
Figure 2.11	<i>WOB lab scale elemental composition of ashes for beech wood / PE</i> .....	21
Figure 2.12	<i>LT-CFB flow diagram (simple version with a hot 2<sup>nd</sup> cyclone for gas cleaning)</i> ...	22
Figure 2.13	<i>500 kW<sub>th</sub> LT-CFB test plant at DTU</i> .....	23
Figure 2.14	<i>100 kW<sub>th</sub> LT-CFB gasifier</i> .....	23
Figure 2.15	<i>Important process temperatures from 100 kW<sub>th</sub> LT-CFB test no. 5</i> .....	26
Figure 2.16	<i>Important process temperatures from 100 kW<sub>th</sub> LT-CFB test no. 6</i> .....	26
Figure 2.17	<i>Important process temperatures from 100 kW<sub>th</sub> LT-CFB test no. 8</i> .....	26
Figure 2.18	<i>Important process temperatures from last 6 hours of 100 kW<sub>th</sub> LT-CFB test no. 8</i> ..	27
Figure 3.1	<i>OLGA equipment selection based on dew points</i> .....	29
Figure 3.2	<i>OLGA scheme</i> .....	30
Figure 3.3	<i>OLGA lab &amp; pilot facility</i> .....	30
Figure 3.4	<i>OLGA pilot scale modifications</i> .....	31
Figure 3.5	<i>ORS scheme</i> .....	32

Figure 3.6	<i>ORS lab &amp; pilot facility</i> .....	32
Figure 3.7	<i>OLGA micro scale facility</i> .....	33
Figure 3.8	<i>OLGA micro scale with RME scrubber</i> .....	34
Figure 3.9	<i>OLGA micro scale with biodiesel scrubber</i> .....	34
Figure 3.10	<i>OLGA micro scale with glycerol scrubber</i> .....	34
Figure 3.11	<i>OLGA performance downstream RDF gasification at 750 &amp; 850°C</i> .....	35
Figure 3.12	<i>OLGA performance downstream beech wood / PE gasification at 550 &amp; 650°C</i> ..	36
Figure 3.13	<i>OLGA performance downstream beech wood / PE gasification at 780 &amp; 850°C</i> ..	36
Figure 3.14	<i>OLGA pilot scale temperature profile</i> .....	37
Figure 3.15	<i>OLGA pilot scale performance downstream the MILENA gasifier</i> .....	38
Figure 3.16	<i>ORS lab scale products</i> .....	38
Figure 3.17	<i>ORS lab scale separation of thermoplast from collector oil</i> .....	38
Figure 3.18	<i>ORS pilot scale effect of dust/tar ratio on oil viscosity</i> .....	39
Figure 3.19	<i>ORS pilot scale recovery yield of the light fraction at 320°C</i> .....	40
Figure 3.20	<i>LT-CFB 100 kW<sub>th</sub> basic OLGA working principle</i> .....	44
Figure 4.1	<i>Results from partial oxidation experiments</i> .....	48
Figure 4.2	<i>Yields of naphthalene, phenanthrene and anthracene (left) as well as pyrene, benzanthracene and chrysene (right) as function of the excess air ratio</i> .....	48
Figure 4.3	<i>CFD simulation of evaporative cooler for the 100 kW<sub>th</sub> LT CFB gasifier</i> .....	50
Figure 4.4	<i>Test of nozzle (left), evaporative cooler without insulation (centre) and evaporative cooler with insulation (right)</i> .....	50
Figure 4.5	<i>Diagram of the filtration set-up</i> .....	51
Figure 4.6	<i>Bag house filter</i> .....	51
Figure 4.7	<i>Diagram of the gas cleaning set-up</i> .....	52
Figure 4.8	<i>Schematic drawing of the partial oxidation reactor</i> .....	52
Figure 4.9	<i>The Petersen Column setup</i> .....	53
Figure 4.10	<i>Partial oxidation (POX) and tar sampling setup</i> .....	53
Figure 4.11	<i>Stable isotope dilution illustrated by the analysis of naphthalene</i> .....	54
Figure 4.12	<i>Work-up and stable isotope dilution illustrated by the analysis of naphthalene</i> ....	54
Figure 4.13	<i>Gas cooler temperatures from tests during gasifier operation on pectin residues</i> ..	55
Figure 4.14	<i>Inside view of the cooler after operation</i> .....	56
Figure 4.15	<i>Ash &amp; sand particles collected from the bottom of the gas cooler</i> .....	56
Figure 4.16	<i>Measurement of pressure drop across back house filter on September 24<sup>th</sup> 2009</i> ..	56
Figure 4.17	<i>Measurement of pressure drop across back house filter on November 18<sup>th</sup> 2009</i> ..	57
Figure 4.18	<i>Picture of an unused bag and a bag after the filtration experiments</i> .....	57
Figure 4.19	<i>The POX temperatures during the experiments</i> .....	58
Figure 4.20	<i>Gas composition of producer gas leaving the POX</i> .....	59
Figure 4.21	<i>Overall tar content of producer gas leaving the POX reactor</i> .....	59
Figure 4.22	<i>PAH-tar content of producer gas leaving the POX reactor</i> .....	60
Figure 5.1	<i>MILENA 10 MW<sub>th</sub> tar removal efficiency for different gasification temperatures</i> ..	62
Figure 5.2	<i>Principal diagram of Low Temperature gasifier with gas cooling and gas filter</i> ..	62
Figure 5.3	<i>Compact cooler design for gas coolers below 10 MW<sub>th</sub> (left) and cooling tower design for gas coolers above 10 MW<sub>th</sub> (right)</i> .....	63

## Summary

In the project “tar removal from low-temperature gasifiers” two gas cleaning technologies are adapted and tested in connection to low-temperature gasification. These concern the OLGA tar removal technology developed by the Dutch partners in the project and the cooling, filtration and partial oxidation developed by the Danish partners in the project.

This project aimed at judging the technical and economical suitability of two up-scalable tar removal methods (OLGA and Partial Oxidation) connected to high-efficiency low-temperature gasification. Suitability opens the way to high efficient and high fuel flexible biomass gasification systems for the connection to gas engines, gas turbines, fuel cells or catalytic synthesis gas reactors.

### Low temperature gasification

In this project, low-temperature gasification refers to 800°C or below. Fluidized bed reactors operated at 800°C or below usually show poor carbon conversion resulting in both low efficiency and waste problems (carbon containing ash). By using the technology of coupled reactors, both Danish and Dutch researchers succeeded in combining low-temperature gasification with high carbon conversion.

The Danish concept called Low-Temperature Circulating Fluidized Bed (LT-CFB) uses a second coupled reactor called “char reaction chamber” where char from fast pyrolysis is converted at low temperature (typically 750°C) due to the high residence time. The Dutch indirect MILENA gasification concept uses a second coupled reactor where air is introduced to burn the remaining char.

From the tar composition at different gasification temperatures it can clearly be observed that oxygen containing phenolic model compounds such as phenol, cresol and naphthols are significantly converted when the temperature is increased from 750°C to temperatures above 850°C. Non-oxygen containing aromatic or polyaromatic model compounds, however, are not reduced that significantly or are even increasing in content with increasing temperature. This can be explained by the fact that biomass tars are made up from a wide variety of compounds. The most reactive compounds containing heteroatoms like N and O and/or pendant groups react first, with the result that the remaining tars end up with a different composition. Ultimately, to convert the last tars (the polycyclic aromatic hydrocarbons) always present in biomass tars cracking needs to take place at the temperatures required to crack naphthalene, phenanthrene, and anthracene and would require higher temperatures, typically between 850 and 1200°C. At lower temperatures, 550 and 650°C, the amount of conventional non-polar tars are relatively low, while the polar tars as well as tars undetectable by gas chromatography dominate the tar spectrum.

The trend in the main gas composition is the increase of the unsaturated hydrocarbons acetylene and ethylene, as well as benzene and methane with increasing gasification temperature from 550 to 850°C. The increase of the first three is probably caused by cracking of more heavy polar tars at higher temperature, whereas the increase of methane might be affected more by some methanation related reactions. One can however expect a decrease of these components when the temperature is increased further. Concerning ash, the cyclone ashes for gasification at over 750°C have a significant higher ash content compared to the ash for gasification at 550°C. The latter contain far more carbon due to the limited carbon conversion during gasification at lower temperature. At higher temperatures, more chlorine ends up in the cyclone ash.



## Oil based gas washing (OLGA)

The OLGA not only removes tars, but also dust as well as contaminants like thiophenes and dioxins from the product gas of a (biomass) gasifier. Although originally designed for tar removal downstream gasifiers operated at 800-900°C, the OLGA technology has been tested downstream gasifiers operated at lower temperatures as well, showing that OLGA is not limited to gasifiers operated at 800-900°C. At lower temperatures, the tar composition shifts from large multiple ring tar components with high dew points to smaller single or double ring tar components with lower dew points. Furthermore, the tar composition will shift from rather stable non-polar components towards reactive polar components. As OLGA was originally designed to remove mainly non-polar tars, application of OLGA downstream gasifiers operated at lower temperatures will require some modifications. The key issues refer to tar polymerisation, oil stability and viscosity, aerosol formation and capture, and overall performance of the tar removal technology.

As such, the cooling section between gasifier and OLGA requires some specific attention. Although the dew point of the tars formed is lower, the amount of tars is significantly higher and in particular for an indirect gasifier like the MILENA. More importantly, the tars are much less stable; hence the risk of tar polymerization is significantly higher. As this polymerization is strongly depending on temperature and residence time, one should avoid condensation as far as possible and after condensation reduce the temperature as quickly as possible. As such, the cooling capacity of the OLGA collector has to be increased slightly in order to cope with the higher inlet temperature of the gas to OLGA.

The oil stability and viscosity, controlled by the ORS, depend on the amount and composition of the tars as well as the amount of fine solids entering the OLGA. In order to be able to pump this liquid product, the amount of fine solids and the amount of (heavy) tars should be in the right proportion. At the same time, all fine solids will be present at a certain stage in the collector oil loop, and hence influence the viscosity of this oil. Although the content of fine solids in the product gas of a low temperature gasifier is not that different from a gasifier operated at higher temperatures, the recovery yield of the ORS will have to be optimised in a complete different way for a low temperature gasifier, due to the reduction of in particular the amount of heavy tars formed in the gasifier. The more heavy tars or dust are present in the gas, the higher the recovery yield for light tars of the ORS will have to be in order to control the viscosity. The target for this optimisation is having a viscosity of 100 cP or lower, which means that in the collector oil loop a dust concentration of 5 to 10% is acceptable, whereas for the (heavy) tar fraction obtained from the ORS this dust fraction can be significantly higher.

At low temperature gasification the tar composition will shift from rather stable non-polar components towards highly reactive polar components. As OLGA was originally designed to remove mainly non-polar tars, application of OLGA downstream gasifiers operated at lower temperatures will also require some modifications in the absorber stripper section of the OLGA. These modifications mainly focus on changing the conventional absorption oil applied in OLGA or implementing another oil absorption step supplementary to the existing one. As long as the temperature of the gasification is in a range of 750 to 850°C, there is no real need to change oils or add columns. When the gasification temperature is 650°C or even lower, the tar slip of an OLGA with conventional oils will be too high, and (additional) gas scrubbing with a different oil will be required to maintain the same tar removal efficiency. This (additional) oil for low-temperature gasifiers can be glycerol (preferred above RME and biodiesel), however can also be some form of polar tar condensate.

## Filtration and partial oxidation

The purpose of this study is to prove that it is possible to filter the gas from a LT CFB gasifier in a commercially available bag house filter at temperatures around 300 °C. The traditional way to clean the gas from the LT-CFB gasifier includes only cyclones. This approach leaves a considerable amount of particles in the gas, and thereby limits the potential usage. If the last particles were removed the gas could be used for multiple additional purposes in gas boilers, and other equipment that does not tolerate particles.

Previous studies have shown that the tar dew point of gas from the LT-CFB gasifier is somewhere between 190 and 250 °C. As it is possible to purchase affordable and commercially available bag house filters that functions in temperatures as high as 370 °C, it seemed reasonable to conduct the filter experiments with gas temperatures above the tar dew point. At these temperatures clogging of the bag house filters by liquid tars is avoided.

The study also focuses on the reduction of tars via partial oxidation. The producer gas leaving a biomass gasifier normally contains more or less tar depending on the design of the gasifier and the type of biomass used as fuel. The partial oxidation of the gas results in a significantly reduction of the tar. Primary and secondary tars are oxidized or converted to tertiary tars during this partial oxidation. The partial oxidation of the pyrolysis gas can be recognized as one of the main reasons for the almost “tar-free” producer gas from a staged gasifier.

## System assessment

In order to determine the effect of the gasification temperature on the design of the tar removal several systems are assessed. For MILENA and OLGA, a predesign is made of the OLGA for a 10 MW<sub>th</sub> combined heat and power plant. For the comparison, gasification temperatures are chosen, at which it is expected that the OLGA will not require an additional column for the removal of specific polar components. Decreasing the gasification temperature does not have an immediate effect on the required column heights, as it is still possible to have a sufficient tar removal by increasing the amount of absorption oil. Lowering the gasification temperature from approximately 880 to 775°C would require approximately 20% additional oil in the absorber loop, corresponding to an increase of the diameter of the absorber and stripper column with less than 5%. It therefore can be concluded that lowering the gasification temperature in the MILENA has not a large influence on the design of the columns in OLGA, hence the capital costs. The temperature decrease in the gasifier however already broadens the choice of biomass feedstock significantly, allowing also the application of a feedstock with an ash melting temperatures around 800°C. When the gasification temperature is decreased further to below 650°C, something that might be necessary to apply feedstock's like straw and grass with much lower ash melting points, the need for an additional scrubbing column will increase the costs of the OLGA. In general though, the increased capital costs will be compensated by the lower costs of the feedstock and the increased overall efficiency when operating at lower temperatures.

Based on the successful tests of cooling the gas and particle filtration it seems very likely that also a robust gas cooling and cleaning system can be implemented for a LT-CFB gasifier. Besides the OLGA mentioned above, different designs of evaporative coolers can be applied. For smaller plants (below 10 MW<sub>th</sub>) the Danish design used in the current project is recommended. This is a compact design: The cooler is below 6 m tall. However for larger volumes than 10 MW one shall then consider to use a cooling tower design, where the hot gas enters from the top and water is sprayed into the gas from the side. The evaporative cooling principle is especially an advantage if low temperature heat (district heat) is to be generated, as the energy used for cooling the gas is recovered in a condensing flue gas unit.



# 1. Introduction

## 1.1 Background

Biomass is considered an important source of renewable energy needed to realise national and European renewable energy goals and goals for CO<sub>2</sub> reduction. Biomass gasification as a technology is recognized generally as highly desirable because of its high efficiency towards all kind of energy products. Biomass can be gasified using many different technologies ranging from high-temperature processes as high as 1500°C to low-temperature processes as low as 500°C. This project focuses at gasification processes below 800°C. These so-called low-temperature biomass gasification processes have following advantages:

- Suitable for (generally cheap) fuels with low ash melting points;
- High cold gas efficiency due to less heat loss and less energy demand for heating;
- Low tar dew point<sup>1</sup> resulting in less cooling and fouling problems compared to “traditional” fluidized bed gasifiers at typically 850-950°C;
- Easier gas cooling and cleaning due to small content off vaporized ash components present in the raw gas;
- For some processes longer residence times due to lower reaction rates, resulting in less stringent specifications of fuel composition/homogeneity and on fuel feeding;
- Less heat transfer limitations within gasifier enabling operation at elevated pressure.

## 1.2 Problem definition

The main disadvantage of low-temperature gasification is the relatively high tar level in the gas. This is why these processes generally are not considered being suitable for connection to gas engines, gas turbines, fuel cells or catalytic synthesis reactors. All the advantages mentioned previously however, urge researchers to develop gas cleaning systems that can handle the higher tar content and as such can extend the application of low-temperature gasifiers from simple co-firing to also the mentioned applications.

## 1.3 Objective

In this project, two gas cleaning technologies are adapted and tested in connection to low-temperature gasification. These concern (1) OLGA and (2) cooling, filtration and partial oxidation. Figure 1.1 schematically shows the scope of the project.

This project aimed at judging the technical and economical suitability of two up-scalable tar removal methods (OLGA and Partial Oxidation) connected to high-efficiency low-temperature gasification. Suitability opens the way to high efficient and high fuel flexible biomass gasification systems for the connection to gas engines, gas turbines, fuel cells or catalytic synthesis gas reactors.

Figure 1.2 shows different gasification temperature regions on the basis of tar dew point and tar yield. Being able to handle tars in the 700-800°C interval would be very attractive. This temperature is high enough to have limited tar yield and low enough to have an acceptable tar dew point.

---

<sup>1</sup> The tar dew point is the temperature at which tars start condensing upon cooling the gas. Low-temperature tars are not similar to the high-temperature tars. High-temperature tars contain high amounts of poly-aromatic hydrocarbons that have high boiling points (condensation at high temperature). Low-temperature tars contain much smaller molecules, often including hetero-atoms (highly water soluble compounds). This means that tar dew points are much lower.




Figure 1.1 Scope of project




Figure 1.2 Effect of temperature on tar yield & dew point

## 1.4 Approach

This project includes six participants relevant in the field of low-temperature gasification and/or gas cleaning, more specifically tar removal. Two participants are from the Netherlands and mainly focus on MILENA gasification and OLGA gas cleaning (ECN and Dahlman) and four participants are from Denmark (Dall Energy, Risø DTU, DFBT and Anhydro) and mainly focus on LT-CFB gasification and cooling, filtration and partial oxidation.

Within the project, three work packages (WP) are defined. WP1 has the objective to have OLGA successfully remove tars from low-temperature gasification, WP2 has the objective to verify that particles after low-temperature gasification can be filtered in a bag filter and that the tar content can be reduced considerably by partial oxidation and WP3 has the objective to assess the systems based on low-temperature gasification and quantify the advantages over similar more “traditional” systems.

By having both Dutch and Danish partners participating in all three work packages and determine process operating conditions the originally separately developed gas cleaning technologies can be adapted and tested in connection to both the also originally separately developed gasification technologies.

## 1.5 Reading instructions

The structure of this report is as follows:

- Chapter 2 describes the applied gasification concepts as well as the obtained results by both the Dutch and the Danish partners;
- Chapter 3 describes the oil based gas washing concept applied by the Dutch partners as well as the modifications required and the results obtained downstream low-temperature gasification processes;
- Chapter 4 describes the gas filtration and partial oxidation concept applied by the Danish partners as well as the modifications required and the results obtained downstream low-temperature gasification processes;
- Chapter 5 provides a system assessment of the different gas cleaning technologies downstream the different gasification concepts;
- Chapter 6 summarises the conclusions and recommendations of this study.

## 2. Low-temperature gasification

In this project, low-temperature gasification refers to 800°C or below. Fluidized bed reactors operated at 800°C or below usually show poor carbon conversion resulting in both low efficiency and waste problems (carbon containing ash). By using the technology of coupled reactors, both Danish and Dutch researchers succeeded in combining low-temperature gasification with high carbon conversion.

The Danish concept called Low-Temperature Circulating Fluidized Bed (LT-CFB) uses a second coupled reactor called “char reaction chamber” where char from fast pyrolysis is converted at low temperature (typically 750°C) due to the high residence time. The Dutch indirect MILENA gasification concept uses a second coupled reactor where air is introduced to burn the remaining char.

The technologies as well as the applied operating conditions and the results obtained are described in this chapter. Besides the MILENA and LT-CFB gasification technologies, also results with the bubbling fluidized bed gasifier WOB are presented. The WOB gasifier has been applied by ECN as this facility offered also the opportunity to be operated stable at temperatures of 650°C and lower.

### 2.1 Indirect air/steam-blown MILENA gasification

The first design of the MILENA gasifier was made in 1999. The first cold flow, for hydrodynamic testing, was built in 2000. Financing a lab-scale installation appeared to be problematic, because there was no interest in a new gasification technology at that time. This changed when Substitute Natural Gas (SNG) was identified as a promising bio-fuel and the indirect MILENA gasification process was identified as a promising technology for the production of SNG<sup>[1]</sup>. The construction of a 30 kW<sub>th</sub> MILENA installation (Figure 2.2 on the left) was started in 2003. The installation was finished and taken into operation in 2004. Financing of the 800 kW<sub>th</sub> MILENA pilot plant (Figure 2.2 on the right) was approved in 2006 and the construction was finished in 2008<sup>[2]</sup>.

#### 2.1.1 Description of MILENA

The MILENA gasifier contains separate sections for gasification and combustion. Figure 2.1 shows a simplified scheme of the MILENA process. The gasification section consists of three parts, *i.e.* the riser (1), the settling chamber (2) and the downcomer (3). The combustion section contains three parts, the bubbling fluidized bed combustor (4), the freeboard (5) and the sand transport zone (6). The arrows in Figure 2.1 represent the circulating bed material. The processes in the gasification section will be explained first.

Biomass (*e.g.* wood) is fed into the riser. A small amount of superheated steam is added from below. Hot bed material (in normal operating mode sand or olivine with a temperature of typically 925°C) enters the riser from the combustor through a hole in the riser opposite and just above the biomass feeding point. The bed material heats the biomass to 850°C, converting the biomass particles into gas, tar and char. The volume created by the gas from the biomass results in an increase of the vertical velocity, creating a “turbulent fluidization” regime in the riser and carrying over of the bed material together with the degasified biomass particles (char).

The vertical velocity of the gas is reduced in the settling chamber, causing the larger solids (bed material and char) to separate from the gas and fall down into the down comer. The producer gas leaves the reactor from the top and is sent to the cooling and gas cleaning section. Typical residence time of the gas is several seconds.




Figure 2.1 MILENA scheme




Figure 2.2 MILENA lab & pilot facility

The combustor operates as a bubbling fluidized bed (BFB). The downcomer transports bed material and char from the gasification section into the combustor. Tar and dust, separated from the producer gas, are also returned to the combustor. Char, tar and dust are burned with air to heat the bed material. Flue gas leaves the reactor to be cooled, de-dusted and emitted. The heated bed material leaves the bottom of the combustor through a hole into the riser. In normal operation mode, no additional heat input is required; all heat required for the gasification process is produced by the combustion of the char, tar and dust in the combustor.

The hot producer gas from the gasifier contains several contaminants, such as dust, tar, chloride and sulphur, which have to be removed before it can be applied in downstream applications like gas engines and turbines or catalytic conversion into for example bio-SNG. Tar compounds condense when the gas is cooled, which makes the gas very difficult to handle, especially in combination with dust. The producer gas is cooled in a heat exchanger, designed to treat gas which contains tar and dust. The heat is used to pre-heat combustion air. Tar and dust are removed from the gas in the downstream OLGA gas cleaning section (described in Chapter 3).

### 2.1.2 Applied operating conditions

Indirect gasifiers like the MILENA theoretically are operated at an equilibrium based on the temperature dependence of the char yield in the gasifier: char yield decreases with temperature. Since this char is combusted to produce the heat, this leads to an equilibrium where char yield matches the energy demand of the gasification<sup>[3]</sup>. Typically this results in a temperature within the riser of 850°C and within the combustor of 925°C. Lowering the temperature in the riser inevitably results in more remaining char<sup>[4]</sup>, which is sent to the combustor, hence increasing the temperature in the combustor.

In order to maintain the lower temperature in the riser, as desired in low temperature gasification concepts, some form of cooling is required. On lab scale, this is relatively easy as heat loss from the process is compensated by high temperature electrical trace heating and external insulation. Switching off the electrical trace heating would increase the heat loss on the combustor, hence lowering the equilibrium temperature levels in both the riser and the combustor with roughly 100°C.

Alternatively, the biomass supply to the gasifier can be lowered, and the initial moisture content of the biomass or the amount of fluidization gas in the riser can be increased. Tests on lab scale showed that the temperature of within the riser could be lowered to approximately 650°C. Stable operation of the gasifier at lower temperatures could not be achieved unless active cooling would be installed on the combustor wall.

As the gas composition of the lab scale MILENA gasifier operated at these temperatures of 650°C was considered not to be representative for actual commercial low temperature gasification, tests on MILENA lab scale were only performed at temperatures in the riser between 735 and 880°C. In order to verify the suitability of the OLGA tar removal downstream gasifiers operated at even lower temperature, hence producing significant amounts of polar in stead of non-polar tars, also tests were performed with the lab scale direct air-blown WOB gasifier, which can be operated more easily at lower temperatures (described in §2.2).

On pilot scale, no external heat supply to the reactor has been installed, as the goal for the pilot plant is to realize an installation which can be used to do experiments under realistic commercial conditions<sup>[2]</sup>. This also means an increase in fuel particle size from 1–3 mm for the lab scale installation to < 15 mm for the pilot plant. Like the lab scale facility the pilot plant facility is not equipped with an active cooling on the combustor side. As such, gasification at temperatures in the riser below 750°C can (not yet) be achieved. Different tests are performed within a range of 750 to 880°C, similar to the tests performed with the lab scale MILENA.

### 2.1.3 Experimental results

The tests with the MILENA lab scale gasifier are based on beech wood as feedstock. Two test campaigns were done, one in which catalytically active olivine was applied as bed material and one in which sand was used. The temperature in the riser was varied over 100°C. For the tests with sand as bed material, the lowering of the temperature was achieved mainly by switching off the trace heating. The additional N<sub>2</sub> fed to the riser, in order to maintain the same gas velocity in the riser, also contributed to the cooling. The data on the gas composition as presented in Table 2.1, hence have to be corrected for the dilution caused by this N<sub>2</sub> (Table 2.2). The same is done for the detailed tar analysis as presented in Figure 2.3 and Figure 2.4. For the pilot scale MILENA, similar data are presented in Figure 2.5. These data are from two representative tests with the MILENA being operated at approximately 800 and 830°C on clean wood pellets, sand as bed material and air on the riser.

Table 2.1 *MILENA lab scale gas composition*

Feedstock Bed material Temperature <sup>2</sup>	[°C]	Beech wood Olivine						Beech wood Sand			
		776	782	832	861	880	882	735	775	819	861
CO	[mol% <sub>dry</sub> ]	29.3	30.4	29.7	31.4	27.5	28.4	28.8	33.0	37.1	39.3
H <sub>2</sub>	[mol% <sub>dry</sub> ]	22.0	21.4	22.8	20.7	27.3	24.9	10.7	13.8	17.1	21.4
CO <sub>2</sub>	[mol% <sub>dry</sub> ]	23.9	24.0	24.2	24.9	24.8	25.5	9.3	10.7	12.0	13.9
CH <sub>4</sub>	[mol% <sub>dry</sub> ]	10.5	10.8	10.3	10.6	9.5	9.5	9.2	10.9	12.1	12.8
C <sub>2</sub> H <sub>2</sub>	[mol% <sub>dry</sub> ]	0.3	0.3	0.3	0.5	0.2	0.3	0.2	0.3	0.4	0.5
C <sub>2</sub> H <sub>4</sub>	[mol% <sub>dry</sub> ]	4.3	4.6	4.3	4.1	3.4	3.5	3.0	3.8	4.4	4.4
C <sub>2</sub> H <sub>6</sub>	[mol% <sub>dry</sub> ]	0.6	0.6	0.3	0.2	0.2	0.1	0.5	0.5	0.4	0.2
C <sub>6</sub> H <sub>6</sub>	[Vppm <sub>dry</sub> ]	7343	7885	8851	10233	9551	9636	4268	6736	9155	12179
C <sub>7</sub> H <sub>8</sub>	[Vppm <sub>dry</sub> ]	2006	1907	1468	1088	944	811	1635	1846	1513	1303
N <sub>2</sub>	[mol% <sub>dry</sub> ]	3.8	4.6	3.4	4.0	3.1	3.6	35.2	24.8	15.5	5.6
<b>Tars <sup>3</sup></b>											
Class 2 tars	[mg/m <sub>n</sub> <sup>3</sup> <sub>dry</sub> ]	4613	4082	1987	1073	982	486	4472	4932	3680	1462
Class 3 tars	[mg/m <sub>n</sub> <sup>3</sup> <sub>dry</sub> ]	209	287	253	299	197	158	404	541	482	275
Class 4 tars	[mg/m <sub>n</sub> <sup>3</sup> <sub>dry</sub> ]	8405	9521	12071	15049	11406	11689	4816	10334	17391	18579
Class 5 tars	[mg/m <sub>n</sub> <sup>3</sup> <sub>dry</sub> ]	1088	1352	2004	3222	2147	2289	395	1321	3413	5010
Unknowns	[mg/m <sub>n</sub> <sup>3</sup> <sub>dry</sub> ]	6118	6796	5094	5307	3642	3052	7240	7923	8258	6556

<sup>2</sup> The temperature presented is the temperature within the settling chamber of the MILENA gasifier and is considered to be the most accurate for describing the actual gasification temperature.

<sup>3</sup> The tars are subdivided into five tar classes (more information on the Thersites website <http://www.thersites.nl>). Class 1 tars are GC undetectable tars, including the heaviest tars that condense at high temperature even at very low concentrations. Class 2 tars consist out of heterocyclic components (like phenol, pyridine, cresol) that generally exhibit high water solubility, due to their polarity. Class 3 tars are light aromatic components that are not important in condensation and water solubility issues. Class 4 tars are light polyaromatic hydrocarbons (2-3 rings) that condense at relatively high concentrations and intermediate temperatures. Class 5 tars are heavy polyaromatic hydrocarbons (4-5 rings) that condense at relatively high temperature at low concentrations.



Table 2.2 *MILENA lab scale tar concentration normalised to 0% N<sub>2</sub>*

Feedstock Bed material Temperature	[°C]	Beech wood Olivine						Beech wood Sand			
		776	782	832	861	880	882	735	775	819	861
CO	[mol% <sub>dry</sub> ]	30.5	31.9	30.7	32.7	28.4	29.5	44.4	43.9	43.9	41.6
H <sub>2</sub>	[mol% <sub>dry</sub> ]	22.9	22.4	23.6	21.6	28.2	25.8	16.5	18.4	20.2	22.7
CO <sub>2</sub>	[mol% <sub>dry</sub> ]	24.8	25.2	25.1	25.9	25.6	26.5	14.4	14.2	14.2	14.7
CH <sub>4</sub>	[mol% <sub>dry</sub> ]	10.9	11.3	10.7	11.0	9.8	9.9	14.2	14.5	14.3	13.6
C <sub>2</sub> H <sub>2</sub>	[mol% <sub>dry</sub> ]	0.3	0.3	0.3	0.5	0.2	0.3	0.3	0.4	0.5	0.5
C <sub>2</sub> H <sub>4</sub>	[mol% <sub>dry</sub> ]	4.5	4.8	4.5	4.3	3.5	3.6	4.6	5.1	5.2	4.7
C <sub>2</sub> H <sub>6</sub>	[mol% <sub>dry</sub> ]	0.6	0.6	0.3	0.2	0.2	0.1	0.8	0.7	0.5	0.2
C <sub>6</sub> H <sub>6</sub>	[Vppm <sub>dry</sub> ]	7633	8265	9163	10659	9857	9996	6586	8957	10834	12901
C <sub>7</sub> H <sub>8</sub>	[Vppm <sub>dry</sub> ]	2085	1999	1520	1133	974	841	2523	2455	1791	1380
Tars normalised to 0% N <sub>2</sub>											
Class 2 tars	[mg/m <sub>n</sub> <sup>3</sup> <sub>dry</sub> ]	4795	4279	2057	1118	1013	504	6901	6559	4355	1549
Class 3 tars	[mg/m <sub>n</sub> <sup>3</sup> <sub>dry</sub> ]	217	301	262	311	203	164	623	719	570	291
Class 4 tars	[mg/m <sub>n</sub> <sup>3</sup> <sub>dry</sub> ]	8737	9980	12496	15676	11771	12126	7432	13742	20581	19681
Class 5 tars	[mg/m <sub>n</sub> <sup>3</sup> <sub>dry</sub> ]	1131	1417	2075	3356	2216	2374	610	1757	4039	5307
Unknowns	[mg/m <sub>n</sub> <sup>3</sup> <sub>dry</sub> ]	6360	7124	5273	5528	3759	3166	11173	10536	9773	6945




Figure 2.3 *MILENA lab scale tar composition for beech wood & sand*




Figure 2.4 *MILENA lab scale tar composition for beech wood & olivine*




Figure 2.5 MILENA pilot scale tar composition for clean wood pellets & olivine (air on riser)

From the tar composition at different gasification temperatures it can clearly be observed that oxygen containing phenolic model compounds such as phenol, cresol and naphthols are significantly converted when the temperature is increased from 750°C to temperatures above 850°C. Non-oxygen containing aromatic or polyaromatic model compounds, however, are not reduced that significantly or are even increasing in content with increasing temperature. This can be explained by the fact that biomass tars are made up from a wide variety of compounds. The most reactive compounds containing heteroatoms like N and O and/or pendant groups react first, with the result that the remaining tars end up with a different composition. Ultimately, to convert the last tars (the polycyclic aromatic hydrocarbons) always present in biomass tars cracking needs to take place at the temperatures required to crack naphthalene, phenanthrene, and anthracene and would require higher temperatures, typically between 850 and 1200°C<sup>[5]</sup>.




Figure 2.6 Relation between tar dew point and concentration

Looking at the effect of temperature on the different classified tars (Table 2.2), a trend can be observed that the content of class 2 tars significantly decreases when the temperature is increased from 700 to 850°C, class 3 tars are relatively stable in this temperature area and that the content of class 4 and 5 tars in the gas initially increases (till a temperature of approximately 860°C) before decreasing at higher temperatures. Considering this trend and the tar dew points of the specific tar classes (as presented in Figure 2.6<sup>[6]</sup>), the bell shaped curve of the tar dew point as presented in Figure 1.2 can easily be explained.

The effect of the changing tar quantities and composition on OLGA is discussed in more detail in Chapter 3. Due to the limitations in operating temperatures of both the lab and pilot scale MILENA gasifiers, no research was performed on indirect gasification at temperatures below 735°C and the effect this would have on tar formation. Results of direct gasification at temperatures even below 700°C are however reported in §2.2 on lab scale WOB gasification as well as §3.2.3 on micro scale OLGA experiments.

## 2.2 Direct air-blown WOB gasification

The “biomass fluidized bed research facility” WOB is the oldest fluidized bed test facility within the current lab-scale test park at ECN. The WOB has been used for the gasification of many different fuels and mixtures, but has also been proven to be suitable for both the pyrolysis and combustion of these fuels and mixtures. Among the fuels tested are wood, straw, RDF and manure. Like with the MILENA gasifier, the WOB gasifier is connected to almost all lab facilities available and hence extensively used as a fuel gas generator for research on downstream gas cleaning and conditioning equipment.

### 2.2.1 Description of WOB

The WOB gasifier is an atmospheric bubbling fluidized bed gasifier with a feedstock capacity of approximately 1 kg/h. The gasifier is electrically heated and has an internal diameter of 74 mm in the bubbling fluidized bed section, increasing to 108 mm in the freeboard section at a height of 500 mm (Figure 2.7). The total length is 1100 mm from the metal distributor plate to the product gas outlet. In the product gas outlet a small cyclone is positioned for removal of the bulk of the ash leaving the gasifier. Downstream this cyclone, a hot gas filter (HGF, Figure 2.8) and the lab scale OLGA facility (Chapter 3, Figure 3.3) are installed.




Figure 2.7 WOB scheme



Figure 2.8 WOB lab facility with HGF

Although the WOB has been used for pyrolysis, gasification and combustion, operation at low temperatures has a certain drawback. At low temperature, whether it is pyrolysis or gasification, the biomass is not fully converted. As a result unconverted char will accumulate in the bed, causing an increase of the bed as it is not possible to drain the bed during operation of the WOB. Furthermore, the char might act as catalyst for tar cracking reactions, resulting for long test runs in different tar compositions for the lab scale WOB compared to a commercial BFB.

### 2.2.2 Applied operating conditions

The tests with the WOB operated as low temperature gasifier were originally scheduled to be based on the application of refuse derived fuel (RDF). Feeding this feedstock to the WOB had been done already in previous experiments<sup>[7]</sup>, and the RDF is considered to be an interesting fuel for low temperature gasification as specific contaminants present in the (waste stream) RDF would not end up in the product gas. Due to some chlorine and plastics related issues briefly discussed later on (§3.3), it became difficult to perform an extensive testing campaign on RDF and it was decided to operate the gasifier on a mixture of beech wood and polyethylene (PE). This mixture resembles RDF, without having a large amount of chlorine present in the gas. As such it provided the necessary information for low temperature gasification and tar removal, while avoiding the chlorine issues observed during gasification of RDF. Table 2.3 summarises the applied operating conditions of the low temperature gasification tests that will be discussed in this report.

Table 2.3 WOB lab scale operating conditions

Abbreviation	Feedstock	WOB temperature	Remarks
RDF-750	RDF	750°C	Only OLGA collector applied downstream
RDF-850	RDF	850°C	Only OLGA collector applied downstream
BWPE-550	Beech wood + 10 wt.% PE	550°C	Complete OLGA applied downstream
BWPE-650	Beech wood + 10 wt.% PE	650°C	Complete OLGA applied downstream
BWPE-780	Beech wood + 10 wt.% PE	780°C	Complete OLGA applied downstream
BWPE-850	Beech wood + 10 wt.% PE	850°C	Complete OLGA applied downstream

In all tests, the WOB was operated on air and steam, while applying (non-catalytic) sand as bed material. The hot gas filter, applied in all tests, was operated on a temperature level of 450°C and coated with kaolin. The kaolin is not expected to be catalytically active for tar cracking.

## 2.2.3 Experimental results

### 2.2.3.1 Tar composition

In Figure 2.9 the tar composition of the (N<sub>2</sub> rich) product gas is presented for the tests with wood and PE as well as with RDF. As the RDF contains significant amounts of polystyrene (in the form of Styrofoam), this graph is dominated by the styrene peak. In Figure 2.10, therefore, the same composition is presented while limiting the range of the tar content scale.




Figure 2.9 WOB lab scale tar composition for RDF and for beech wood / PE (bulk)




Figure 2.10 WOB lab scale tar composition for RDF and for beech wood / PE (detailed)

For the RDF gasification at 750 and 850°C, besides the specific styrene peak, a similar trend can be observed as with the beech wood gasification tests with MILENA; phenol levels decrease with increasing temperature, whereas naphthalene (and associated components like acenaphthylene and phenanthrene) increase. Also the behaviour of the tars classified as unknowns is similar. And although the total tar concentration due to the gasification of the (waste stream) RDF increased significantly, taking into account that the data presented are not corrected for the nitrogen content, the absolute levels are not a priori causing concerns for the performance of OLGA downstream this RDF gasification (as will be shown in §3.3).

The RDF tests encountered condensation though of an unusual thermoplast in the temperature area of 150 to 200°C. Although the thermoplast softens and melts upon heating similar to tars, its liquid viscosity is much higher compared to “conventional” tars. It is thought<sup>[8]</sup> that the reaction towards the thermoplast could be attributed to the combined presence of (i) the polystyrene in the RDF fuel, (ii) the also highly present chlorine as a catalyst for the polymerization reactions and (iii) at least one other tar component, likely released from another component present in the RDF fuel. To verify this thesis, a chlorine removal step was successfully demonstrated downstream the WOB gasifier and upstream the OLGA. The chlorine removal based on a sodium carbonate impregnated alumina oxide carrier was hence operated above the tar dew point of the product gas. It should be noted that the chlorine content in the product gas was extremely high, up to several volume percent. When applying more “conventional” fuels, these (problematic) chlorine levels will not be reached.

During the gasification tests with a mixture of beech wood and PE, it was decided to lower the gasification temperature far below the initial temperature range set for this project. At 780 and 850°C, the trend is the same as in all previous described tests, *i.e.* phenol decreasing and naphthalene increasing. The total tar levels changed significantly compared to the RDF gasification test, clearly as the beech wood and PE are both relatively clean fuels. At lower temperatures, 550 and 650°C, the amount of conventional non-polar tars decreases significantly while the polar tars (mainly classified as unknowns-2) as well as tars undetectable by GC (unknowns-1) dominate the tar spectrum. It is specifically because of these tars that basic OLGA design will require some modifications (§3.2.3).

### 2.2.3.2 Main gas composition

The main composition of the product gas for the gasification of the mixture of beech wood and PE is presented in Table 2.4. The measurement of the gas composition of the raw product gas at 550°C was complicated due to continuous fouling of the pre-sampling system operated at 5°C.

Table 2.4 WOB lab scale main gas composition for beech wood / PE

mol%	H <sub>2</sub>	N <sub>2</sub>	CH <sub>4</sub>	CO	CO <sub>2</sub>	C <sub>2</sub> H <sub>2</sub>	C <sub>2</sub> H <sub>4</sub>	C <sub>2</sub> H <sub>6</sub>	C <sub>6</sub> H <sub>6</sub>	C <sub>7</sub> H <sub>8</sub>
BWPE-550	3.2	56.5	3.7	10.3	20.4	0.0	0.6	0.6	0.07	0.04
BWPE-650	8.1	52.1	4.1	10.5	19.4	0.0	1.6	0.5	0.12	0.05
BWPE-780	7.3	51.0	5.2	17.0	13.8	0.2	3.7	0.3	0.41	0.11
BWPE-850	11.8	45.8	6.1	16.2	15.3	0.3	3.7	0.4	0.52	0.07
mol% N <sub>2</sub> free	H <sub>2</sub>	N <sub>2</sub>	CH <sub>4</sub>	CO	CO <sub>2</sub>	C <sub>2</sub> H <sub>2</sub>	C <sub>2</sub> H <sub>4</sub>	C <sub>2</sub> H <sub>6</sub>	C <sub>6</sub> H <sub>6</sub>	C <sub>7</sub> H <sub>8</sub>
BWPE-550	7.4	–	8.5	23.7	46.9	0.0	1.4	1.4	0.2	0.1
BWPE-650	16.9	–	8.6	21.9	40.5	0.0	3.3	1.0	0.3	0.1
BWPE-780	14.9	–	10.6	34.7	28.2	0.4	7.6	0.6	0.8	0.2
BWPE-850	21.8	–	11.3	29.9	28.2	0.6	6.8	0.7	1.0	0.1

The main trend observed is the increase of the unsaturated hydrocarbons acetylene and ethylene, as well as benzene and methane with increasing gasification temperature. The increase of the first three is probably caused by cracking of the more heavy polar tars at higher temperature, whereas the increase of methane might be affected more by some methanation related reactions. One can however expect a decrease of these components when the temperature is increased further, like what was seen during the MILENA tests (§2.1.3) and what seems to be happening already for ethane and toluene in the WOB gasification tests performed at 750°C and higher.

### 2.2.3.3 Ash composition

During the low gasification tests with beech wood and PE, four ash samples were collected and analysed, *i.e.* cyclone ash after the tests performed at 780 and 850°C, cyclone ash during and after the tests performed at 550°C, and bed ash at the end of all tests. The cyclone ash for gasification at 780-850°C has a significantly higher ash content compared to the ash for gasification at 550°C, 75% vs. 52% (Table 2.5). The latter sample contains far more carbon due to the limited carbon conversion during gasification at lower temperature.

Table 2.5 WOB lab scale ash composition for beech wood / PE

Type	Temperature	Carbon	Hydrogen	Nitrogen	Ash	Chlorine
Cyclone	780-850°C	24.4 wt.%	0.3 wt.%	0.06 wt.%	75 wt.%	0.03 wt.%
Cyclone	550°C	38.6 wt.%	1.4 wt.%	0.16 wt.%	52 wt.%	0.02 wt.%
Bed	550-850°C	—	—	—	69 wt.%	0.33 wt.%

The high concentration of alumina present in the cyclone ashes (Figure 2.11) finds its origin in the kaolin (alumina silicate) added to the gasifier in order to coat the HGF. In both the cyclone and the bed ash chlorine has been detected. The elemental analysis of the ashes (Figure 2.11) also reveals that besides alumina (and silica) from kaolin also high amounts of potassium, calcium, magnesium and iron are present in the ash.




Figure 2.11 WOB lab scale elemental composition of ashes for beech wood / PE

At higher temperatures, more chlorine would end up in the cyclone ash. Based on a general composition of beech wood obtained from the Phyllis database and the main mass balance over the gasifier during the tests, it is estimated that at higher temperatures approximately 1/8<sup>th</sup> of the chlorine ends up in the cyclone ash, whereas at lower temperatures this is more 1/30<sup>th</sup>.

## 2.3 Direct air-blown LT-CFB gasification

The LT-CFB gasification process has been described in detail in earlier publications<sup>[9,10,11]</sup> and will here only be described shortly (Figure 2.12). Fuel particles with a top size of typically around 3 mm are introduced into the pyrolysis chamber and are there rapidly pyrolysed at e.g.  $\sim 650^{\circ}\text{C}$ . The pyrolysis takes place due to good thermal contact with mainly re-circulated sand and ash particles. Due to the low temperature and retention time in the pyrolysis chamber essentially only light tars and no PAH are formed.

The residual char, pyrolysis gasses and inert particles are blown upwards to the primary cyclone, which separates char and inert particles to a bubbling bed char reactor. Here the char is gasified at typically  $\sim 730\text{--}760^{\circ}\text{C}$  using mainly air as the gasification agent. Some steam or water may also be added in order to improve the conversion of char. Due to the low and very stable temperature only little ash melting takes place and therefore agglomeration problems can be avoided even when using only ordinary silica sand as the bed material.




Figure 2.12 LT-CFB flow diagram (simple version with a hot 2<sup>nd</sup> cyclone for gas cleaning)

The char gas produced leave the top of the char reactor along with fine ash particles and this stream enter the pyrolysis chamber, where the char gas contributes to the high gas velocity in the upper part. Heavier inert particles in the form of sand and/or coarse ash re-circulate to the pyrolysis chamber from the bottom of the char reaction chamber while acting as a heat carrier. This way, the heat liberated due to the mainly exothermic reactions in the char reactor is transferred to the mainly endothermic processes in the pyrolysis chamber.

The exit stream out of the pyrolysis chamber has an even lower temperature compared to the temperature in the char reactor. Consequently, nearly all alkalines and similar ash components are retained in the solid state and therefore such components are separated roughly as efficient as the particles entering the cyclones.



Neither heating nor heat absorption surfaces are needed anywhere in the process and of course all complications and potential problems related to such surfaces are therefore avoided. Ash particles may re-circulate several times but eventually the main part will typically escape through the primary cyclone and be separated by the more efficient secondary cyclone. A potential further coarser ash stream may be drained from the bottom of the gasifier, and in these two ways, typically around 95% of the ash is usually retained.



Figure 2.13 500 kW<sub>th</sub> LT-CFB test plant at DTU

Up to now, three LT-CFB test plants have been build and operated at DTU in Denmark. In chronologic order their capacities defined as nominal fuel input are 50, 500 and 100 kW<sub>th</sub>. A photo of the 500 kW<sub>th</sub> plant is seen in Figure 2.13. Experiences achieved with the 500 kW<sub>th</sub> plant have earlier been published in e.g. Paris <sup>[12]</sup>.

The basis for the Danish part of the experimental work relevant to this ERA-NET Bioenergy project is a number of tests conducted with the new 100 kW<sub>th</sub> LT-CFB test plant which was operated for the first time during this project. The 100 kW<sub>th</sub> plant seen in Figure 2.14 was coupled to gas cleaning equipment elaborated in Chapter 4. The gasifier is the part in aluminium foil, while the blue barrels are the (elevated) fuel bin and the bin for ash separated by the secondary cyclone.



Figure 2.14 100 kW<sub>th</sub> LT-CFB gasifier



### 2.3.1 Applied operating conditions

The full present extent of operating the 100 kW<sub>th</sub> LT-CFB plant can be seen in Table 2.6. Some important data for the 3 fuels use in tests no 3-8 are included in Table 2.7. The bed-material used during all of the 8 tests was ordinary silica sand “Dansand no. 13”<sup>[4]</sup>.

Table 2.6 *All of the present 8 test with the new 100 kW<sub>th</sub> LT-CFB plant*

Test no. and time	Fuel	Operating hours at beyond 700°C in char gasifier / hours with bag filter	Type of gas cleaning	Overall results & comments
1) 28. May 2009	Straw, hammer milled	0 / 0	Sec. cyclone (SC)	Feeding problems
2) 24.-25. June 2009	Straw, hammer milled	4,5 / 0	Sec. cyclone (SC)	Load limited by feeding problems
3) 8.-9. July 2009	Straw, pelletise and crushed	22 / 0	Sec. cyclone (SC)	First long and stable operation of the 100 kW LT-CFB gasifier
4) 8.-9. Sept. 2009	Straw, pelletise and crushed	17 / 1	Sec. cyclone (SC) and filter	1 hour test of slip stream cooler and filter. Some new feed system problems solved.
5) 23.-24. Sept 2009	Straw, pelletise and crushed	28 / 6	SC, cooler and filter	Long and efficient operation on straw and first long and successful cooling and filtration test.
6) 17.-18. Nov. 2009	Residue fibers mainly from citrus shells, pelletise and crushed	25 / 7	SC, cooler and filter	Up to > 110% load at high efficiency on this new LT-CFB fuel. Gas cooling and filtering again successful
7) 15.-16. Dec. 2009	Residue fibers mainly from citrus shells, pelletise and crushed	12 / 6	SC, cooler and filter	Leak from primary cyclone day 1. Error in PLC program day 2.
8) 13.-15. Jan. 2010	Straw, pelletise and crushed	52 / 16	SC, cooler, filter and POX	Longest stable and efficient operation on straw. Filter exit duct (but not cooler and filter) eventually blocked due to bad electrical heat tracing

Table 2.7 *Data for fuels use in 100 kW LT-CFB tests nos. 3-8*

Fuel	Crushed pellets, approx. top size mm	Moisture as received %	Ash in dry matter %	P / K / Cl in dry matter %	Lower heating value as recieved MJ/kg
Straw for tests nos. 3-5	3	7.7	5.2	0.051 / 1.0 / 0.4	16.01
Residue fibers for tests no 6 and 7	3	8.3	13.1	0.082 / 0.5 / 0.061	14.92
Straw for tests no. 8	3	8.3	5.9	0.1 / 1.1 / 0.24	15.82

In order to simulate longer term operation, the bed material was reused between all of the first 5 tests on straw. Then a fresh charge of the same type of sand was loaded for the test nos. 6 and 7. Eventually, the bed-material from test no. 5 was reloaded before the last test no. 8.

<sup>4</sup> The suppliers specification can be downloaded from [http://www.dansand.dk/cust/215/DOK/upload/S\\_V\\_13.pdf](http://www.dansand.dk/cust/215/DOK/upload/S_V_13.pdf)

As can be seen from Table 2.6, the very first two tests in May and June 2009 did not result in stable operation at full load. Besides dealing with various minor problems of practical nature (being usual for such a fully new test plant), the main problem was feeding loose hammer milled straw into the gasifier. Instead of wasting more time on attempting to avoid the blocking of the probably too narrow downwards connecting duct between the upper metering double screw and the lower faster rotating feeding screw, it was decided to instead feed the straw in the form of crushed pellets. This was done in all of the tests numbered 3 to 8.

The new choice of fuel preparation led to the first operation at close to full load at July 8<sup>th</sup> and 9<sup>th</sup> 2009 and during the test no. 4 some further initial experiences with the new plant was gained, e.g. the functionality of the added gas cooling and cleaning system was initially tested.

As planned within a “parallel” Danish PSO-2007 project, the 6<sup>th</sup> and 7<sup>th</sup> test were on a fuel prepared from residue fibres from the Danish company CP-Kelco, which produces pectin and caregenan based on respectively citrus shells. However, only the first of the two tests on these residue fibres (mainly from citrus shells) resulted in the intended many hours of operation. In the afterwards test no. 7 operation had to be terminated after some 12 hours due to a leak in the primary cyclone. During a restart the second day it was discovered that an error had been added to the PLC-programme which made further operation impossible.

The last 100 kW<sub>th</sub> test no 8 was partly financed by a Danish PSO-2009 project led by DONG Energy, which is the reason why the fuel was now again straw and again it was in the form of crushed pellets. The aim was primarily to achieve many hours of stable and efficient operation at close to 100 % load and this way gain a better basis for evaluating the need for so called “bed particle management”, e.g. including the need for draining ash particles accumulated in the bed-material.

### 2.3.2 Experimental results

A 1<sup>st</sup> important result to be mentioned is that during all of the 8 conducted 100 kW<sub>th</sub> tests, it was again possible to avoid ash melting problems. This was in spite of the mentioned choices of:

- just using plain silica sand as the bed-material,
- not applying any other additives,
- the stated extensive re-use of bed-material.

In the late part of last test no 8 automatic temperature control on the char reaction chamber was successfully activated and a stepwise temperature increase was realised by increasing the temperature set point. The temperature increase to slightly above 760°C was also done in order to investigate if there was still a margin to the temperature that would result in de-fluidisation in the char reaction chamber and/or disturbed particle circulation. Fortunately, no problems appeared even though an afterward analysis of the bed material showed that potassium had accumulated to the level of 8.0%. This result, - showing the LT-CFB gasifiers capability of using even very difficult young agricultural fuels such as straw, - is consistant with the experiences gained with the two former 50 and 500 kW LT-CFB test plants. The mentioned 8 % potassium is however breaking an old “record” of 5.2% potassium in the bed material.

The 100 kW<sub>th</sub> tests nos. 5, 6 and 8 is considered the most interesting in relation to the ERA-NET Bioenergy project activities concerning gas cooling and cleaning, i.e. further gas processing downstream the LT-CFB’s hot secondary cyclone. The full extent of operation during these 3 tests is illustrated by the 3 important process temperatures shown in Figure 2.15 to Figure 2.17.




Figure 2.15 Important process temperatures from 100 kW<sub>th</sub> LT-CFB test no. 5




Figure 2.16 Important process temperatures from 100 kW<sub>th</sub> LT-CFB test no. 6




Figure 2.17 Important process temperatures from 100 kW<sub>th</sub> LT-CFB test no. 8

The temperatures in Figure 2.15 to Figure 2.17 may not seem very stable, but this is mainly due to many short stops for refilling the fuel bin and the high compression of the time axis. The stability is better seen from Figure 2.18, showing the last approximately 6 hours of test no 8.




Figure 2.18 Important process temperatures from last 6 hours of 100 kW<sub>th</sub> LT-CFB test no. 8

The highest of the temperatures shown in all of the four figures above “KRT-2” is measured in the bubbling fluidized bed in the char reaction chamber. Here the temperature must be high enough to allow efficient char conversion without too much addition of steam/water, but preferably not so high that too much KCl evaporates and never so high that problematic ash melting takes place. The intermediate temperature “PKT-4” is measured in the pyrolysis chamber near the level of fuel feeding. Here the temperature must be high enough to achieve fast and efficient pyrolysis (leaving a small char residue) but not so high that PAH forms due to tar cracking. The last temperature, “SCT-ind” is measured between the two cyclones. Here it is important to keep the temperature down in order avoid that e.g. KCl escapes through the cyclones in gas phase. Some further results focussing on the 100 kW<sub>th</sub> LT-CFB gasifier, e.g. including performance data, will be presented in the report being prepared in the parallel PSO-2007 project.



### 3. Oil based gas washing (OLGA)

The oil based gas washing (OLGA) developed by ECN and Dahlman not only removes tars, but also dust as well as contaminants like thiophenes and dioxins from the product gas of a (biomass) gasifier [13, 14]. At ECN, the OLGA technology is currently applied within the Substitute Natural Gas (SNG) production process based on indirect gasification. As OLGA removes tars, but not the valuable lighter hydrocarbons like methane, acetylene, and ethylene, it plays a crucial role in high-efficient SNG production processes. The OLGA in the past has been demonstrated successfully upstream Fischer-Tropsch (FT) diesel synthesis and in Combined Heat and Power (CHP) line ups as well though [13].

Although originally designed for tar removal downstream gasifiers operated at 800-900°C, the OLGA technology has been tested downstream gasifiers operated at lower temperatures as well, showing that OLGA is not limited to gasifiers operated at 800-900°C. As shown in Chapter 2, though, at lower temperatures, the tar composition shifts from large multiple ring tar components with high dew points to smaller single or double ring tar components with lower dew points. Furthermore, the tar composition will shift from rather stable non-polar components towards reactive polar components.

As OLGA was originally designed to remove mainly non-polar tars, application of OLGA downstream gasifiers operated at lower temperatures will require some modifications. In this chapter, these modifications and the experimental results obtained with them are described in §3.2 and 3.3. It is also described how the OLGA can be integrated with the LT-CFB gasifier (§3.4). The chapter starts though with a short description of the OLGA (§3.1).

#### 3.1 Description of OLGA

The philosophy of OLGA is all about dew point control [15]. In Figure 3.1, the tar and water dew points are shown, together with the logical process steps. First, the product gas is cooled from the outlet temperature of the gasifier (typically 700–900°C) to the OLGA inlet temperature just above the tar dew point of the gas. Upstream OLGA, coarse solids are separated via cyclones. Fine solid aerosols are removed by OLGA. In OLGA, the tars are separated, first by condensation of heavy tars by cooling the gas from just above the tar dew point of the gas to just above the water dew point and secondly by absorption of light tars. The key philosophy in this is operating OLGA above the water dew point, while decreasing the tar dew point to a level under the lowest process temperature. As such, conventional water-based scrubbing technologies can be applied without mixing water and tars.




Figure 3.1 OLGA equipment selection based on dew points

The tar removal principle of OLGA is based on a multiple stage scrubber, as shown in Figure 3.2, in which the gas is cleaned by special scrubbing oil. In the first section of OLGA (the collector), the gas is gently cooled down by the scrubbing oil. Heavy tar condenses, is collected, and is separated from the scrubbing oil. The heavy tar condensate together with the fine solids is recycled to the gasifier as a liquid. In the second stage (the absorber/stripper), lighter gaseous tars are absorbed by the scrubbing oil resulting in a product gas practically free from tars and solids. In the absorber column, the scrubbing oil is saturated by these lighter tars. This saturated oil is regenerated in a stripper. Normally, hot air is used to strip the tars of the scrubbing oil.




Figure 3.2 OLGA scheme

This air used for stripping the absorber oil, hence loaded with light tars, is recycled to the gasifier for combusting and as fluidization medium. Hence, the stripper column design is not only based on tar removal, but also on the amount of air that can be used by the gasifier. All heavy and light tars can be recycled to the gasifier where they are destructed and contribute to the energy efficiency. Tar waste streams are efficiently recycled this way. Between the collector and the absorber, a wet electrostatic precipitator (wet-ESP) is installed to remove fine solid aerosols from the product gas (as shown on the left of the picture of the OLGA pilot facility, Figure 3.6). This w-ESP is not necessary when a high efficient solid removal step (*i.e.* a hot gas filter) is applied upstream OLGA, as for example is the case in the OLGA lab facility.



Figure 3.3 OLGA lab & pilot facility



## 3.2 Required modifications for low-temperature gasification

In order to take full advantage of low-temperature gasification, the OLGA must be modified to deal with different tars and higher concentrations than what OLGA originally has been designed for. The key issues refer to tar polymerisation, oil stability and viscosity, aerosol formation and capture, and overall performance of the tar removal technology. In the following paragraphs, the modifications required to (a) the cooling section, (b) the oil handling, and (c) the tar removal are discussed. The results of experiments performed after these modifications are described in §3.3.

### 3.2.1 The cooling section: the gas cooler and OLGA collector

The cooling section of an integrated system of biomass gasification and OLGA tar removal consist out of two sections; the actual gas cooler downstream the biomass gasifier and the tar condensation step of OLGA, *i.e.* the collector. Although the outlet temperature of the gasifier is lower for low-temperature gasification and also the tar dew point is lower compared to “traditional” fluidized bed gasifiers operated at typically 850–950°C, the cooling section requires some specific attention.

Although the dew point of the tars formed is lower, the amount of tars is significantly higher and in particular for an indirect gasifier like the MILENA. More importantly, the tars are much less stable; hence the risk of tar polymerization is significantly higher. As this polymerization is strongly depending on temperature and residence time, one should avoid condensation as far as possible and after condensation reduce the temperature as quickly as possible. On a pilot scale, this resulted in the reconstruction of the piping and cyclone upstream the OLGA, the actual gas inlet of the OLGA, and the (collector) oil cooling in OLGA (Figure 3.4).




Figure 3.4 OLGA pilot scale modifications

During the testing of the pilot OLGA downstream the 500 kW<sub>th</sub> CFB gasifier BIVKIN in 2006 the operating temperatures of the cyclone and of the gas inlet were 400 and 350°C<sup>[16]</sup>. These temperatures however were only reached by the heating effect of the product gas. During start-up, temperatures were significantly lower, increasing the risk of initial fouling. Although not a serious problem in the duration tests of 2006, it was decided to change the setup in order to be able to operate the cyclone as well as the gas inlet of OLGA at temperatures of 450°C, well above the dew point of the product gas of the MILENA gasifier, hence avoiding any issues with tar condensation and possible polymerization in the piping upstream the OLGA.

As a result of this increased temperature level of the gas entering the OLGA, the cooling duty of the collector column is increased (§3.3.3). In order to cope with this increased cooling duty, the capacity of the collector oil cooling has to be increased. Additional cooling capacity is therefore installed within the collector oil loop, using the already existing connections of the superfluous oil filters within this collector oil loop of the pilot OLGA. The oil filters became superfluous due to the application of the oil recovery system (§3.2.2).



### 3.2.2 The oil handling: the oil recovery system (ORS)

The oil recovery system (ORS) is designed in order to separate dust as well as the heavy fraction of the tars from the collector oil loop, while maintaining the light fraction of the tars within this loop. As such, it is capable of (a) removing the surplus of tars collected from the product gas, (b) removing any dust slipped through the cyclones and/or HGF upstream OLGA, and (c) controlling the viscosity of the oil in the collector loop. The ORS allows operation on collector oil with a constant viscosity, without the need for supply of fresh collector oil. Furthermore, as the ESP is integrated into the collector oil loop, it enables complete dust removal from the collector oil, hence the product gas.

The principle of the ORS is based on partial evaporation of the collector oil (Figure 3.5). The vaporous lighter fraction is sent to the gas inlet of OLGA by a sweeping gas and hence kept within the OLGA collector loop. The heavy fraction, including fine solids, is pumped out of the ORS as a liquid stream suitable as *e.g.* feedstock for the gasifier. The pumping of this liquid stream also sets demands to the viscosity of this stream; hence the ORS ultimately controls both the viscosity of the collector oil and of the surplus of tars extracted from the OLGA.




Figure 3.5 ORS scheme



(lab)



(pilot)

Figure 3.6 ORS lab & pilot facility

In the design of the ORS, the amount of fine solids entering the OLGA, as well as the amount and composition of the tars plays a crucial role. In principle, all fine solids as well as the (heaviest) tars end up as a liquid product of the ORS. In order to be able to pump this liquid product, the amount of fine solids and the amount of (heavy) tars should be in the right proportion. At the same time, all fine solids will be present at a certain stage in the collector oil loop, and hence influence the viscosity of this oil. Although the content of fine solids in the product gas of a low temperature gasifier is not that different from a gasifier operated at higher temperatures, the ORS will have to be optimised in a complete different way for a low temperature gasifier, due to the reduction of in particular the amount of heavy tars formed in the gasifier (as seen in Chapter 2).

### 3.2.3 The tar removal: the OLGA absorber and stripper

At low temperature gasification the tar composition will shift from rather stable non-polar components towards highly reactive polar components (as seen in Chapter 2). As OLGA was originally designed to remove mainly non-polar tars, application of OLGA downstream gasifiers operated at lower temperatures will also require some modifications in the absorber stripper section of the OLGA. These modifications mainly focus on changing the conventional absorption oil applied in OLGA or implementing another oil absorption step supplementary to the existing one. To study the operation of alternative oils as absorber liquids, a small (micro) scale pyrolysis was constructed in connection with a very basic small scale OLGA (Figure 3.7).




Figure 3.7 OLGA micro scale facility

The experimental apparatus consists of three parts. The first part is the pyrolysis stage, the second the cleaning stage and the third the tar collection stage. Within the cleaning stage, rapeseed methyl ester (RME), biodiesel, and glycerol were tested as alternative absorption oil. Experiments were also performed with the liquids mentioned in combination with the conventional OLGA collector and absorber oil. The column with the liquids under investigation was herefore placed between the collector and the presently used absorber column.

Both the tar protocol guideline<sup>[17]</sup> as the solid phase adsorption method (SPA) can be applied. The advantages of the SPA method compared to the conventional cold trapping method used by the guideline include sampling speed, simplicity, less solvent consumption, faster workup, accuracy and repeatability<sup>[18]</sup>. The guideline, however, is preferred, as a significant amount of polar tars is expected which can not be determined via the SPA method<sup>[19]</sup>.

## 3.3 Experimental results

### 3.3.1 OLGA micro scale

The micro scale OLGA was mainly used to determine the possibility to use OLGA downstream gasification at very low temperature (*e.g.* pyrolysis) or gasification at varying temperatures (*e.g.* updraft gasification). The fuel used in the micro scale gasifier (Figure 3.7) to produce the product gas is beech wood and the temperature was set at 400°C. Close to this point mostly carbonyls, alcohols and ethers, in general more polar compounds, are produced<sup>[20,21]</sup>. During three tests, RME, biodiesel and glycerol are applied in order to remove these components from the product gas. In Figure 3.8 to Figure 3.10, the removal efficiency is presented, also showing that some components are already removed by the oils conventionally applied in the OLGA collector and absorber.




Figure 3.8 OLGA micro scale with RME scrubber




Figure 3.9 OLGA micro scale with biodiesel scrubber




Figure 3.10 OLGA micro scale with glycerol scrubber

When only one column containing the alternative scrubbing liquid RME, biodiesel or glycerol is used, the cleaning efficiency  $\eta$  (representing the amount of tars absorbed-collected in the liquid(s) over the total amount of tars produced, including those which were condensed and did not pass through the cleaning stage) was found to be 33% for the RME and 73% for the glycerol. This is an implication that both liquids may improve the efficiency towards removal of “polar” tar compounds, although glycerol seems to be much more efficient than RME. Biodiesel was only studied in combination with a conventionally operated collector and absorber. The new column with the biodiesel was placed between the collector and the presently used absorber column. The results showed that the efficiency ( $\eta$ ) under these conditions was 58% for OLGA in combination with a biodiesel scrubber. For RME under similar setup, this was 44%. Again glycerol showed to be more efficient, with an overall efficiency of OLGA and the glycerol scrubber of 94%.

### 3.3.2 OLGA lab scale

Tests with the OLGA on lab scale were performed downstream the WOB gasifier operated at lower temperatures (§2.2) without modifying the OLGA, hence applying the conventionally used oils. Due to the initial problems with chlorine in the product gas<sup>5</sup>, only the collector of OLGA was applied downstream the RDF gasification tests. During the gasification of beech wood and PE, the complete OLGA was applied. In Figure 3.11 the tar composition of the product gas of RDF gasification at 750 as well as 850°C is presented, both downstream the WOB gasifier and downstream the OLGA collector. As the collector is designed in order to cool the gas to a temperature just above the water dewpoint, the collector mainly removes the heavier tar components. The lighter tar components are only removed fractionally in the collector and should normally be removed in the absorption step of OLGA. Besides the issues with the chlorine based thermoplast formation, no issues with OLGA downstream the RDF gasifier were observed. The efficiency of the absorber was not tested though during the RDF gasification.




Figure 3.11 OLGA performance downstream RDF gasification at 750 & 850°C

<sup>5</sup> During the RDF gasification tests, condensation was encountered of an unusual thermoplast in the temperature area of 150 to 200°C. Although the thermoplast softens and melts on heating similar to tars, its liquid viscosity is that high compared with “conventional” tars that it plugged the collector column of the OLGA<sup>[13]</sup>. It is thought that the reaction towards the thermoplast can be attributed to the combined presence of (i) the polystyrene in the RDF fuel, (ii) the also highly present chlorine as a catalyst for the polymerization reactions, and (iii) at least one other tar component, likely released from another component present in the RDF fuel<sup>[8]</sup>. Although the thermoplast can be removed from the oil via the ORS (§3.3.4), chlorine removal upstream OLGA is preferred. By removing chlorine upstream the OLGA, formation of the thermoplast could successfully be avoided and tar removal with OLGA operated as expected and without any further problems<sup>[13]</sup>.

In Figure 3.12 and Figure 3.13 the tar composition of the product gas of the gasification of the beech wood and PE mixture at 550, 650, 780 and 850°C is presented. In this case, however, the composition is provided for the raw product gas as well as the gas after the absorber of the OLGA, hence downstream the full OLGA. During these tests, no problems occurred within the operation of the OLGA. The captured tars at low temperature gasification, though of a more polar nature, are even captured quite well, and no phase separation of either the collector oil or the absorber oil could be observed during the tests.

At the lower gasification temperatures, in particular at 650°C and lower, there's a significant slip of (polar) tar components. All conventional (non-polar) tars are removed nearly completely, as expected. Adding an additional scrubbing stage, based on a polar absorption oil (like described and tested in §3.3.1), will almost certainly lead to total tar removal efficiencies as required by downstream prime movers or synthesis applications. This additional oil could be the tested glycerol (preferred above RME and biodiesel), however could also be some form of own tar condensate.




Figure 3.12 OLGA performance downstream beech wood / PE gasification at 550 & 650°C




Figure 3.13 OLGA performance downstream beech wood / PE gasification at 780 & 850°C



### 3.3.3 OLGA pilot scale

On the OLGA pilot scale, modifications were initially made to the cyclone and the OLGA gas inlet, all in order to be able to operate these sections at higher temperatures than during the duration tests with the OLGA pilot in 2006<sup>[16]</sup>. As such it should be possible to operate the OLGA downstream the MILENA gasifier (with a significantly higher tar content) as well as downstream low temperature MILENA gasification (avoiding any risk of polymerization reactions of the more reactive tars, in case they might condense upstream OLGA). Figure 3.14 provides the temperature profile over the OLGA gas inlet and the different collector sections is presented during the integrated tests with MILENA and OLGA in September 2009.





Figure 3.14 *OLGA pilot scale temperature profile*

From this temperature profile it is clear that the modifications were effective; the gas temperature upstream OLGA could be kept near 400°C, well above the expected tar dewpoint. The temperature profile however also made clear a third modification was required. Due to insufficient cooling, the temperature of the collector oil increased in time, and as a result the temperature of all collector sections also steadily increased. Therefore, it was decided that after the integrated tests of MILENA and OLGA in September, an additional cooler (Figure 3.4) should be mounted in the collector oil loop.

The tests with the OLGA presented were the first tests with the pilot OLGA since the duration tests with the atmospheric air blown gasifier BIVKIN and the OLGA tar removal in 2006<sup>[16]</sup>. In between 2006 and the recent tests, the BIVKIN gasifier was decommissioned and replaced by the indirect air-steam blown gasifier MILENA. From the tar composition of the product gas up and downstream the OLGA as presented Figure 3.15 it can be observed though that, although the gasifier applied changed, the OLGA is still capable of reaching over 99% tar removal, reducing the naphthalene concentration in the gas to below 40 mg/m<sub>n</sub><sup>3</sup> and the phenol concentration in the gas to even below the detection limit of the applied analytical equipment (< 2.5 mg/m<sub>n</sub><sup>3</sup>).



### 3.3.4 ORS lab scale

The ORS was first tested on a lab scale, and although positioned in a lam flow cabinet (Figure 3.6), this facility has a capacity already more than sufficient for the lab scale OLGA. The goal of this ORS facility was to demonstrate the technical feasibility of the patented ORS<sup>[22]</sup>, hence separating the collector oil into a light (gaseous) fraction and a (heavy) fraction. For the tests with the ORS, the collector oil from the OLGA pilot scale duration tests<sup>[16]</sup> was initially applied, though after succesfull testing with this oil (Figure 3.16), also more complicated oils were used, *i.e.* the oil from the lab scale OLGA after the tests downstream RDF gasification as well as pilot scale duration tests mixed with substantial levels of (fine) dust.



The tests with the “contaminated” lab scale OLGA collector oil showed that when cooling the vaporous fraction obtained from the ORS, initially the thermoplast would condense, and only in a later stage of cooling the actually to be recovered components. The viscosity of the thermoplast was still high enough in order not to plug the cooler (Figure 3.17), and hence could be separated from the gaseous fraction that ultimately should be returned to the OLGA collector. Although a promising way to separate the thermoplast “contamination” from the collector oil, research in this field was not continued as avoiding thermoplast formation (by removing chlorine upstream OLGA) should be the preferred alternative (see footnote 5).

The test with the lab scale ORS facility showed that in order to obtain an acceptable recovery rate, the application of a sweep gas would be required, even at temperature levels within the ORS of 280°C or higher. It also revealed that in order to provide sufficient gas-liquid contact time, it would be possible to apply the same materials used in the columns of the OLGA. It will be necessary though to apply more than the one section applied on the lab scale ORS.

### 3.3.5 ORS pilot scale

Based on the experiments with the lab scale ORS therefore a larger ORS facility was constructed, capable of handling the amount of collector oil that has to be treated on the pilot scale OLGA. This pilot scale ORS (Figure 3.6) was commissioned within half a year and used to determine the most critical parameters of the ORS, *i.e.* (i) the acceptable ratios between dust and oil including (heavy) tars, and (ii) the achievable recovery yield.

#### 3.3.5.1 The dust/oil ratio

Within the OLGA, the viscosity of oil and tars plays a crucial role. This relates to both the oil circulating within the collector loop of the OLGA as well as the (heavy) tar separated from the ORS. The viscosity of the oil is determined on the one hand by the tars present in the oil and on the other hand by the dust still present in the raw gas after the cyclone upstream OLGA. Too much dust (or too few tars) will result in an unacceptable increase of the viscosity. In order to determine what dust-to-oil ratios are acceptable, therefore, long time tests with the viscometer installed in the ORS were performed. At the beginning of each test, the dust-to-oil ratio was adjusted, before the dust/oil mixture was pumped around at different temperature levels. The measured viscosity levels during these tests are presented in Figure 3.18, for oil based on 100% pilot duration test oil to oils with increasing amounts of fine dust.




Figure 3.18 ORS pilot scale effect of dust/tar ratio on oil viscosity

Based on the experiences with the OLGA facilities at ECN and in Moissannes, France, an acceptable viscosity of the oil in the collector loop is 100 cP or lower. The lowest temperature level of this oil in the collector loop is approximately 70 to 80°C, *i.e.* just above the water dewpoint of the gas. This means that the maximum acceptable dust concentration in the collector loop is somewhere between 5 and 10%. For the (heavy) tar fraction obtained from the ORS the temperature level will be somewhere between 200 and 300°C. As such, for this dust/tar fraction, a much higher dust content is acceptable.



As such, the critical design parameter of the ORS is the amount of light fraction, separated from the collector oil and send back to the OLGA collector. The more light fraction is separated, the lower the dust/tar ratio becomes, as basically the raw product gas is provided with more condensable tars. The design of the ORS, of course, is strongly depending on the efficiency of the cyclones applied, and the initial tar composition of the gas, *i.e.* the operating conditions of the gasifier.

### 3.3.5.2 The recovery yield

During the tests with the lab scale ORS it was revealed that (with one column section) it would be necessary to operate at a temperature level of over 280C and with an amount of sweep gas in  $l_n/min$  almost equal to the amount of oil to be treated in kg/hr. First tests with the pilot scale ORS (with four active sections) showed that even higher temperatures should be preferred in order to achieve a significant recovery yield.

As research on the ORS is still in the early stages, and exact recovery yields desired are not yet known, as these not only depend on the gasifier, but also on the tar composition (hence gasifier operating conditions), a operating line was determined for the ORS. This operating line, representing the recovery yield of light fraction as a function of the amount of sweep gas applied, is presented in Figure 3.19. In the graph, the recovery yield is determined for both fresh collector oil (as would be used during start-up of an OLGA) as for the pilot duration test oil (already containing relatively more heavy tars).




Figure 3.19 ORS pilot scale recovery yield of the light fraction at 320°C

With expected recovery yields needed of about 40-60% for a MILENA gasifier, the higher values valid for gasification at lower temperatures, it can be concluded that over 0.4  $l_n/min$  sweep gas per kg/hr oil might be needed. Although this amount will not significantly influence the composition and the calorific value of the final product (not even when using nitrogen), the consumption might be considered as that significant that (cleaned) product gas should be applied as sweep gas instead of a gas delivered by a third party. Again, though, this will strongly depend on the gasification plant, size and infrastructures present.

For the MILENA gasification process, the exact conditions for the ORS to be operated on are not yet determined completely. Like for other OLGA designs, the still ongoing research on the ORS will provide significant amount of information on how to optimise the design as well as the operation of the total OLGA system.

### 3.4 Integration of OLGA and LT-CFB

In this paragraph the integration of the OLGA system and the LT-CFB gasifier is described. The theoretical process design of the OLGA system is based on data provided by DFBT and Risø DTU on the 100 kW<sub>th</sub> LT-CFB gasifier. As some specific data has not become available in time for the design, Dahlman has based the design also on a number of assumptions. As such, a number of reservations and recommendations to this design have to be reported (§3.4.3).

#### 3.4.1 Available process input data

The following data are provided by Mr. Stoholm from DFBT and Mr. Ahrenfeldt from Risø DTU

Table 3.1 LT-CFB 100 kW<sub>th</sub> feedstock data

Parameter	Value	Unit	Remarks
Feedstock type	Danish straw		
Feedstock mass flow	19	kg/hr <sub>dry</sub>	
Feedstock moisture content	10	wt. %	
Maximal feedstock moisture content	20	wt. %	Limited by expectable feeding problems

Table 3.2 LT-CFB 100 kW<sub>th</sub> fuel composition

Component	Value <sub>dry</sub>	Value <sub>wet</sub>	Unit	Remark
Heating value	18.5	17.5	MJ/kg	HHV basis
H <sub>2</sub> O (water/moisture)	10		wt. %	
C (carbon)			wt. %	
H <sub>2</sub> (hydrogen)			wt. %	
N <sub>2</sub> (nitrogen)			wt. %	
O <sub>2</sub> (oxygen)			wt. %	
Ash	5		wt. %	Estimate
S (sulfur)			wt. %	
Cl (chloride)			wt. %	
Sum			wt. %	

Table 3.3 LT-CFB 100 kW<sub>th</sub> raw product gas composition (outlet gasifier)

Component	Value <sub>dry</sub>	Value <sub>wet</sub>	Unit
CO <sub>2</sub>	14.5		vol. %
H <sub>2</sub> O <sup>6</sup>	0.0	18.4	vol. %
N <sub>2</sub>	59.0		vol. %
CO	16.3		vol. %
H <sub>2</sub>	3.5		vol. %
O <sub>2</sub>	0.0	0.0	vol. %
CH <sub>4</sub>	4.3		vol. %
C <sub>2</sub> H <sub>y</sub>	1.4		vol. %
C <sub>3</sub> H <sub>y</sub> ... C <sub>5</sub> H <sub>y</sub>	0.3		vol. %
C <sub>6</sub> H <sub>y</sub>	0.0		vol. %
Total gas <sup>7</sup>	99.3		vol. %

Table 3.4 LT-CFB 100 kW<sub>th</sub> stripper / gasifier air or steam

Parameter	Value	Unit	Remark
Type	Air	[-]	
Air mass flow	22	kg/hr	Temperature of 20 °C and Pressure of 0.25 bar(g)
Steam mass flow	-	kg/hr	
Preferred temperature at gasifier inlet	Not specified	°C	
Preferred pressure at gasifier inlet	Not specified	bara	

<sup>6</sup> DTU and DFBT provided a figure of 0.15 kg H<sub>2</sub>O/kg<sub>dry gas</sub>, which is, based on the assumed density of the gas of approximately 1.2 kg/m<sup>3</sup>, calculated to be a water content of 18.4 vol. %.

<sup>7</sup> Raw product gas composition does not include data on argon concentration.

Table 3.5 *LT-CFB 100 kW<sub>th</sub> product gas at inlet OLGA*

Parameter	Value	Unit	Remark
Gas mass flow	43	kg/hr	At approx 90 % load
Gas mass flow (minimal)	30	kg/hr	-30 % (Approx. 60% of 100%)
Gas mass flow (maximal)	52	kg/hr	+20 % (Approx. 110% of 100%)
Normal gas flow	-	m <sub>n</sub> <sup>3</sup> /hr	(m <sub>n</sub> <sup>3</sup> /hr at 0°C and 1 bara) assume e.g. 1,2 kg/m <sub>n</sub> <sup>3</sup>
Normal gas flow (minimal)	-	m <sub>n</sub> <sup>3</sup> /hr	
Normal gas flow (maximal)	-	m <sub>n</sub> <sup>3</sup> /hr	
Actual gas flow	-	m <sub>a</sub> <sup>3</sup> /hr	650 degrees Celsius provided by Mr. Peder Stoholm
Actual gas flow (minimal)	-	m <sub>a</sub> <sup>3</sup> /hr	
Actual gas flow (maximal)	-	m <sub>a</sub> <sup>3</sup> /hr	
Density (normal) Product Gas	1,2	kg/m <sub>n</sub> <sup>3</sup>	Assumption
Density (actual) Product Gas	-	kg/m <sub>a</sub> <sup>3</sup>	
Gas temperature outlet gasifier	650	°C	
Gas inlet temperature OLGA	Not specified	°C	
Water dew point operating	61,5	°C	Calculated, based on water content of 18.4 vol%
Maximal design water dew point	Not specified	°C	
Operating pressure inlet OLGA	1	bara	
Energy content product gas	0,093	MJ	MJ/s assumed!
HHV product gas	7,3	MJ/m <sub>n</sub> <sup>3</sup>	Assumed density: 1.2 kg/m <sub>n</sub> <sup>3</sup>
LHV product gas	8,7	MJ/m <sub>n</sub> <sup>3</sup>	

Table 3.6 *LT-CFB 100 kW<sub>th</sub> solid particles at inlet OLGA*

Parameter	Value	Unit	Remark
Total dust load inlet OLGA operating	0.045	kg/hr	Assumed 80% retention in bed and
Total dust concentration inlet OLGA operating	1257	mg/m <sub>n</sub> <sup>3</sup> <sub>dry</sub>	80% in settling chamber +25%
Maximal dust concentration inlet OLGA maximal	1000-2000	mg/m <sub>n</sub> <sup>3</sup> <sub>dry</sub>	Specified by Dahlman

Table 3.7 *LT-CFB 100 kW<sub>th</sub> tar data (simplified) at inlet OLGA*

Parameter	Value	Unit	Remark
Tar dew point	190	°C	Result from 500 kW test on biogas residue
Total tar mass flow	Not specified	kg/hr	
Tar concentration	4800	mg/m <sub>n</sub> <sup>3</sup> <sub>dry</sub>	Based on LT-CFB #3
Phenol concentration	910	mg/m <sub>n</sub> <sup>3</sup> <sub>dry</sub>	Based on LT-CFB #3
Phenol concentration	769	mg/m <sub>n</sub> <sup>3</sup> <sub>dry</sub>	Calculated, based on LT-CFB #3 and 18.4 vol% H <sub>2</sub> O
Naphthalene concentration	33	mg/m <sub>n</sub> <sup>3</sup> <sub>dry</sub>	Based on LT-CFB #3
Naphthalene concentration	28	mg/m <sub>n</sub> <sup>3</sup> <sub>dry</sub>	Calculated, based on LT-CFB #3 and 18.4 vol% H <sub>2</sub> O
Sum PAH	125	mg/m <sub>n</sub> <sup>3</sup> <sub>dry</sub>	Based on LT-CFB #3

Table 3.8 *LT-CFB 100 kW<sub>th</sub> tar data (composition) at inlet OLGA*

Sample	Unit	LT-CFB #1	LT-CFB #2	LT-CFB #3
Tar gravimetric (80°C 16h)	g/m <sub>n</sub> <sup>3</sup>	38.2	24.2	4.8
Total volatile tar (GCMS)	g/m <sub>n</sub> <sup>3</sup>	33.3	21.9	4.1
Phenol	g/m <sub>n</sub> <sup>3</sup>	1.9	0.72	0.31
Total volatile phenol (GCMS)	g/m <sub>n</sub> <sup>3</sup>	6.0	2.95	0.91
Naphthalene	mg/m <sub>n</sub> <sup>3</sup>	232	108	33
Methyl-naphthalene	mg/m <sub>n</sub> <sup>3</sup>	334	135	72
Acenaphthene	mg/m <sub>n</sub> <sup>3</sup>	12	5.1	2.5
Acenaphthylene	mg/m <sub>n</sub> <sup>3</sup>	32	9.6	7.6
Fluorine	mg/m <sub>n</sub> <sup>3</sup>	30	9.6	4.1
Phenanthrene	mg/m <sub>n</sub> <sup>3</sup>	30	15.4	5.3
Anthracene	mg/m <sub>n</sub> <sup>3</sup>	<0.5	<0.5	<0.5
Fluoranthene	mg/m <sub>n</sub> <sup>3</sup>	0.9	2.6	0.2
Pyrene	mg/m <sub>n</sub> <sup>3</sup>	6.0	6.7	1.1
Sum PAH	mg/m <sub>n</sub> <sup>3</sup>	676	294	125

Table 3.9 *LT-CFB 100 kW<sub>th</sub> inorganic impurities data at inlet OLGA*

Parameter	Value	Unit	Remark
NH3 concentration after gasifier	Not specified	mg/m <sub>n</sub> <sup>3</sup> <sub>dry</sub>	For a detailed OLGA design,
H2S concentration after gasifier	Not specified	mg/m <sub>n</sub> <sup>3</sup> <sub>dry</sub>	types and concentrations should
HCL concentration after gasifier	Not specified	mg/m <sub>n</sub> <sup>3</sup> <sub>dry</sub>	be specified
Other impurities	Not specified	mg/m <sub>n</sub> <sup>3</sup> <sub>dry</sub>	

Based on the data which are discussed with Risø DTU and DFBT, LT-CFB #3 is the most representative tar measurement. The sample is taken during stable operation of the LT-CFB gasifier. Measurements LT-CFB #1 and LT-CFB #2 are taken early in the experiment. Assumed is that the process was not stable, yet, during that time. Above tar data indicate the formation of a large percentage of primary tars and small percentage of secondary and tertiary tars.

As no inorganic data are available, influences (*e.g.* material resistance) are not investigated and not taken into account in the design described in this report. Based on the input (process) data, represented in Table 3.1 to Table 3.9, a theoretical process design of the OLGA system is made. The following topics (results) will be described in the next section:

- Basis and explanation of required outlet concentrations;
- The gas flow range of the OLGA system;
- The operating conditions;

### 3.4.2 Theoretical process design

#### 3.4.2.1 Basis and explanation of required outlet concentrations

Requirements for outlet concentrations are not specified. Therefore, Dahlman has designed the OLGA systems as follows:

- The naphthalene can cause crystallization problems in downstream equipment of the OLGA system. Most critical part is the gas engine; generally speaking a naphthalene concentration of 40 mg/m<sub>n</sub><sup>3</sup> does not cause problems in the gas engine. As the specified inlet concentration is lower than the 40 mg/m<sub>n</sub><sup>3</sup> the focus for the OLGA design is towards phenol.
- The phenol concentration should be minimized. A removal efficiency of 99 percent of the inlet concentration is normally used as starting-point. The last part of phenol can be absorbed in the aqueous scrubber system, which will be placed downstream the OLGA system to remove the inorganic components. Due to the low naphthalene inlet concentration the OLGA system is optimized to the removal of phenol.

Above described approach results in a gas, which is clean enough (based on tar) to run a gas engine and can be achieved according to the theoretical design of the OLGA system.

#### 3.4.2.2 The gas flow range of the OLGA system

The OLGA system is designed for an operating gas flow range of 60–110 percent and the theoretical design is based on a gas flow of 48 kg/hr (100 percent load). Table 3.10 gives an overview of the gas flow ranges.

Table 3.10 *LT-CFB 100 kW<sub>th</sub> gas flow ranges*

Parameter	Value	Unit	Remark
OLGA design flow theoretical design	48	kg/hr	Design capacity at 100 percent
Range percentage theoretical design	60–110	%	
Range mass flow theoretical design	29–53	kg/hr	Capacities at 60-110 percent
Specified minimum gas flow	30	kg/hr	
Specified maximum gas flow	52	kg/hr	

#### 3.4.2.3 The operating conditions

The operating conditions of the OLGA system depend on the tar and water dew point of the gas. The basic principle of the OLGA system is to remove the tars from the gas, so the tar dew point decreases below the water dew point (and lowest process temperature), which results in no tar related problems in downstream equipment. Water and tars should not be not mixed together.




Figure 3.20 *LT-CFB 100 kW<sub>th</sub> basic OLGA working principle*

### **Product gas: Temperature**

Based on, the process input data as described in §3.4.1, and especially Table 3.7 and Table 3.8, an estimate for the tar dew point is made to 300–350 degrees Celsius. This estimate is higher than the tar dew point reported for the LT-CFB in Chapter 4 (200–250°C), as well as the tar dew point specified by DFBT and Risø DTU for the OLGA design when operated on biogas residues (190°C, Table 3.7) mainly on three reasons:

- The specified tar dew point is based on another biomass feedstock;
- The complete tar analysis is not available, yet;
- Unknowns cannot be specified and influence to tar dew point cannot be indicated.

The 300–350 degrees Celsius result in an OLGA gas inlet temperature of 400 degrees Celsius. Based on the specified gas composition and estimated water content of 18.4 vol.%, gas pressure and gas temperature as described in §3.4.1, the water dew point of the gas is determined (Table 3.11). The maximum water dew point cannot be calculated due to a lack of information. Based on the operating case and a safe margin, the theoretical design is made. If more information comes available the water dew point and operating temperature should be evaluated.

Table 3.11 *LT-CFB 100 kW<sub>th</sub> water dew point gas*

	H <sub>2</sub> O [vol.%]	Water dewpoint [@ 1100 mbar(a)]	Unit
Operating case	18.4	61.5	°C
Maximum case	TBD	TBD	°C

### **Product gas: Pressure**

For safety reasons the electrostatic precipitator (ESP) should work on a positive pressure, minimal 5 mbar(g). Based on the air inlet pressure of 1250 mbar(a), an inlet pressure of the OLGA system of approximately 1100 mbar(a) is assumed, which will result in a positive pressure in the ESP.

### **Air: pressure and temperature**

The specified air pressure of 1250 mbar(a) is evaluated in the theoretical process design and based on the current available data, the stripper column can work at this “elevated” pressure. The temperature of the air should be increased from 20 degrees Celsius to 180 degrees Celsius. The second oil loop works as a classical absorber / stripper system. To strip the tars from the oil towards the air, the temperature should be elevated.

In the collector column the gas temperature is decreased to a value which is safely above the water dew point. Heavy tars (secondary / tertiary) will condense in the oil. Dust and possible formed aerosols will be removed in the ESP. In the second loop a classical absorber / stripper system light tars are removed. Phenol and naphthalene are the key components used for the theoretical process design and will be removed as explained at the beginning of this paragraph.

### 3.4.3 Remarks on the design

Based on the (limited) available process data a theoretical process design is made for the OLGA system. The theoretical process design shows that the tars, and especially naphthalene and phenol (key components for design) can be removed to low enough levels that a gas engine should run (based on tars). However, due to the low gasification temperature some reservations and recommendations should be made, namely;

- Complete tar, primary, secondary and tertiary components and  $C_{3+}$ , analysis should be executed. Results should be evaluated;
- Influences of formation of more primary (polar) tar components should be investigated in detail. The removal of primary (polar) tar components in comparison to secondary and tertiary tars is less efficient (they pass through the collector column). Other types of oil for the first oil loop or an additional column with a third oil can possibly be investigated (§3.2.3);
- For good operation of collector column the ratio of dust and heavy tars is important. Based on the available tar and dust data, mixture is not optimal; an increase of the viscosity of the oil is expected. Dust and complete tar data should be investigated in detail.



## 4. Filtration and partial oxidation

### 4.1 Purpose and Background

#### 4.1.1 Bag House Filtration

The purpose of this study is to prove that it is possible to filter the gas from a LT-CFB gasifier in a commercially available bag house filter at temperatures around 300°C. The traditional way to clean the gas from the LT-CFB gasifier includes only cyclones. This approach leaves a considerable amount of particles in the gas, and thereby limits the potential usage. If the last particles were removed the gas could be used for multiple additional purposes, e.g. in gas boilers, and other equipment that does not tolerate particles.

Previous studies have shown that the tar dew point of gas from the LT-CFB gasifier is somewhere between 200 and 250°C. As it is possible to purchase affordable and commercially available bag house filters that functions in temperatures as high as 370°C<sup>[23]</sup>, it seemed reasonable to conduct the filter experiments with gas temperatures above the tar dew point. At these temperatures clogging of the bag house filters by liquid tars is avoided.

#### 4.1.2 Partial Oxidation

The producer gas leaving a biomass gasifier normally contains more or less tar depending on the design of the gasifier and the type of biomass used as fuel. The partial oxidation of the gas results in a significantly reduction of the tar. Primary and secondary tars are oxidized or converted to tertiary tars during this partial oxidation<sup>[24]</sup>. The partial oxidation of the pyrolysis gas can be recognized as one of the main reasons for the almost “tar-free” producer gas from a staged gasifier<sup>[24,25]</sup>.

Other investigations concerning partial oxidation of pyrolysis gas are reported in the literature. Brandt and Henriksen<sup>[26]</sup> investigated partial oxidation of pyrolysis gas produced by straw with focus on the total amount of tar, while Ledesma et al.<sup>[27]</sup> investigated partial oxidation of pyrolysis gas produced by bituminous coal with focus on the formation and fate of polycyclic aromatic hydrocarbons (PAH). In the following sections selected results of these two investigations will briefly be mentioned.

##### 4.1.2.1 Partial oxidation of pyrolysis gas from straw

Brandt and Henriksen<sup>[26]</sup> investigated partial oxidation of pyrolysis gas produced by straw with focus on the total amount of tar. The pyrolysis gas was generated by slow pyrolysis of straw at 600°C with a solid residence time of 23 minutes in the pyrolysis unit. The partial oxidation was carried out at two different temperatures namely at 800 and 900°C. The residence time in the partial oxidation reactor was approximately 2 seconds. In Figure 4.1 results from these partial oxidation experiments are shown. The figure shows the amount of tar collected in the condenser and in the aerosol filter as a function of the excess air ratio at two different oxidation temperatures.






Figure 4.1 Results from partial oxidation experiments

At an excess air ratio (related to the combustion of the volatile pyrolysis products) of 0.3 a considerable reduction of tar can be seen. The minimum tar content measured was 0.5 gram per kg dry straw at 900°C with an excess air ratio of about 0.5. This corresponds to a tar reduction of 98% compared to no addition of air at the same temperature<sup>[26]</sup>. In addition it can be seen that the amount of tar at excess air ratios higher than 0.3 are not changing significantly with respect to temperature. The composition of the tar was not investigated<sup>[26]</sup>. Concerning the gas species after the partial oxidation the investigations also showed that the volume of H<sub>2</sub> and CO given relative to the fuel input were approx. constant with respect to the excess air ratio while the volume of CH<sub>4</sub> was reduced at higher  $\lambda$ <sup>[26]</sup>.

#### 4.1.2.2 Partial oxidation of pyrolysis gas from bituminous coal

Ledesma et al.<sup>[27]</sup> investigated partial oxidation of pyrolysis gas produced by bituminous coal with focus on the formation and fate of polycyclic aromatic hydrocarbons (PAH). These experiments were carried out in a two-stage quartz reactor. In the first stage volatiles that predominantly consisted of primary tar from coal pyrolysis were generated in a fluidized-bed at 600°C with a heating rate in the order of 10<sup>4</sup> K/s. In the second stage the volatiles (primary tar) were reacted under either pyrolytic or oxidizing conditions in a tubular-flow reactor at 1000°C. The residence time in the tubular-flow reactor was approximately 1 second. In Figure 4.2 selected results from the experiments are shown. The mass yields shown are based on the mass of primary tar entering the tubular-flow reactor.




Figure 4.2 Yields of naphthalene, phenanthrene and anthracene (left) as well as pyrene, benzantracene and chrysene (right) as function of the excess air ratio

The investigations carried out by Ledesma et al., showed that the smallest PAH (with two or three fused rings) were present in the largest amounts. In addition the investigation showed that the yields of the lower-ring-number PAH e.g. naphthalene tended to be reduced with higher excess air ratios while the yields of larger-ring-number PAH were increased with respect to the excess air ratio until a certain excess air ratio and hereafter the yields of these were reduced also. The latter can be explained by the following two effects<sup>[27]</sup>:

- Addition of air can favour the PAH formation due to an enhancement of the free radical pool increasing the rate of pyrolytic reactions and thereby PAH formation.
- Enhancement of the oxidizer concentration can lead to oxidation of the PAH and thereby destruction of PAH.

Both of the above mechanisms occur but from the results obtained Ledesma et al. concluded that effect 1 is the dominant one for small amounts of air addition  $\lambda < 0.3$  while effect 2 is the dominant one for  $\lambda > 0.3$ .

## 4.2 Description of the filtration and partial oxidation set-up

To conduct the desired experiments in this work an experimental setup was built. In this section the experimental setup will be presented. In order to apply back house filtration on the gas from the LT-CFB gasifier the gas has to be cooled down below 370°C which is the maximum operating temperature of the filters used<sup>[23]</sup>. To test gas cooling, an evaporation cooler has been built-in after the cyclone (Figure 4.7).

### 4.2.1 Gas cooling prior to bag house filtration

To avoid tar condensation in the gas cooler all surfaces shall be above the tar dew point. As the tar dew point is approx 200-250 °C the media to be used in a standard heat exchanger cannot be water. It has to be pressurized steam, thermal oil or hot air. Such heat exchangers are rather expensive.

A simple and cheap way of cooling hot gases is the use of evaporative cooler: Spraying water droplets into the hot gas and let the evaporative energy of water (2.2 MJ/kg) cool the gas while the water droplets evaporate. Such cooling principle is commonly used in industrial plants when large volumes of hot gases are to be cooled prior bag house filters, such as in cement plants. Two types of water nozzles can be used:


- Two-phase nozzles: where a gas is used to atomize the water. Such nozzles are normally used in large industrial applications, where air is used as the atomizing gas.
- One phase nozzles, where the water is pressurized to a high pressure.

The use of air in a two-phase nozzle in gasification plants is not straight forward as the gas to be cooled is hot and burnable. Alternative gases is nitrogen and compressed gasification gas.

An evaporative cooler was designed for tests. The design was done in co-operation with Spraying Systems, a leading company of evaporative cooling.

As the evaporative cooler (Figure 4.3) was a new design, it was decided to make tests of the cooler separate from tests of the bag filter (Figure 4.4).

## CFD simulation of cooler



**Spraying Systems Co.®**  
Experts in Spray Technology



Spray  
Nozzles



Spray  
Control



Spray  
Analysis



Spray  
Fabrication

Figure 4.3 CFD simulation of evaporative cooler for the 100 kW<sub>th</sub> LT CFB gasifier



Figure 4.4 Test of nozzle (left), evaporative cooler without insulation (centre) and evaporative cooler with insulation (right)

#### 4.2.2 Bag House Filtration

For the tests of the bag filter a slip stream of the gas is cooled in a thermally heated pipe section. The filter is electrically traced. After passing through the filter, the gas is directed through a reactor that is unused for this setup, and which is also electrically traced. Subsequently the gas is directed through a gas blower, followed by a flow measuring device (presented in Figure 4.5).




Figure 4.5 Diagram of the filtration set-up

Measuring the flow of tar containing gases like the one from the LT-CFB gasifier is very difficult, and therefore a rather simple approach is applied in the present setup. The gas is guided through a damper valve, and the pressure drop across the valve is measured.

The damper valve has been pre-calibrated with air, and simultaneous temperature measurements at the damper valve are used as correcting factor in the subsequent flow calculations. Flow measurements done in this way are assumed accurate within  $\pm 25\%$ .

After passing through the damper valve the gas is directed back to the main gas pipe, and the overall pressure drop across the filter section is measured. Finally the filter is back flushed with  $N_2$  to remove the collected particles. The area of the filter is  $0.23 \text{ m}^2$ , and the gas flow for the experiments is adjusted to approximately  $9 \text{ m}^3$  per hour, corresponding to a gas velocity through the filter cloth of  $0.01 \text{ m/s}$ . The same gas velocity is used for the bag-house filter of the Viking TwoStage gasifier<sup>[28]</sup>.



Figure 4.6 Bag house filter

### 4.2.3 Partial Oxidation

During the partial oxidation (POX) experiments (diagram of the setup is presented in Figure 4.7) a small flow of producer gas is mixed with air and nitrogen, just before entering the partial oxidation reactor. The partial oxidation reactor is surrounded by an oven that is electrically heated to the desired temperature. The heating of the oven is done in two zones to accomplish a better temperature control of the partial oxidation reactor.




Figure 4.7 Diagram of the gas cleaning set-up

Preheated air and nitrogen are mixed with the producer gas just before entering the partial oxidation reactor (Figure 4.8). Mass flow controllers are used to control the flow of nitrogen and air and after these the mixed nitrogen and air is preheated typically to a temperature of 600°C. For sampling of the tars after the POX reactor a Petersen Column<sup>[29]</sup> was used, as presented in Figure 4.9. The solvent used was isopropanol.




Figure 4.8 Schematic drawing of the partial oxidation reactor






Figure 4.9 *The Petersen Column setup*



Figure 4.10 *Partial oxidation (POX) and tar sampling setup*

Many tar compounds are available labelled with deuterium or alternatively  $^{13}\text{C}$ . As the first step an appropriate amount of the labelled compound is added to the sample. The amount of internal standard is chosen with respect to the desired carrier effect, which improve chromatography, and the ratio between the analyte and spike required for satisfactory analyses.



## Isotopic equilibrium



GC/MS analysis was performed on a Varian 3400 gas chromatograph interfaced to a Saturn II ion trap mass spectrometer. The temperature of the transfer line (GC to MS) and the manifold of the mass spectrometer was 250 and 200°C, respectively.

The tar compounds were separated using a 0.32 mm x 25m WCOT fused silica column coated with CP-SIL 8CB at a thickness of 0.25  $\mu\text{m}$ . 1  $\mu\text{L}$  samples were introduced in split mode (approximately 1:50) at a temperature of 250°C. Separation of a wide range of compounds was achieved using a temperature program from 50 to 270°C.

## 4.3 Experimental results

### 4.3.1 Gas Cooling

The gas cooler has been tested during gasifier operation on two different fuels, once for operation on straw and once for operation on pectin residues. During both tests the full gas stream was cooled down. Figure 4.13 shows an example of the temperature distribution in the cooler as well as the inlet and outlet temperatures. It can be seen that cooling is achieved as desired and that the temperatures can be controlled. The duration of the cooling tests was limited due to the risk of tar condensation further downstream of the cooler. A part of the downstream piping and the gas burner is placed outside of gasifier-building and thus cold weather enhanced this risk.




Figure 4.13 Gas cooler temperatures from tests during gasifier operation on pectin residues

When inspected after the tests the cooler showed no sign of tar condensation, only a fine layer of dust was seen on cooler walls (Figure 4.14). From the bottom of the cooler some ash and sand particles could be collected but also here no signs of tar condensation were seen (Figure 4.15).





Figure 4.14 Inside view of the cooler after operation



Figure 4.15 Ash & sand particles collected from the bottom of the gas cooler

First the two-phase nozzle principle was tested. Nitrogen was used as atomizing gas. The nozzle used was the type: SUJ12 from Spraying Systems. As the operation of the two-phase nozzle was successful in several tests, it was decided to test a one phase nozzle. The nozzle 1/4N-316SS1.5 from Spraying Systems was selected and tested. Also this worked fine.

#### 4.3.2 Filtration

Five separate filtration tests have been carried out, summing up to a total of 37 hours of gas flow through the bag house filter. As illustrated in Figure 4.16 and Figure 4.17 it has been proved feasible, by this test sequence, to repeatably reduce the pressure drop across the filter to a low stable level by back flushing it with N<sub>2</sub>. The periods with zero pressure drop across the filter indicate no gas flow through the filter (Figure 4.16). In Figure 4.17 the lower rate in pressure drop gain at the end of the measurement indicates a lower amount of particles in that period. The behaviour of the pressure build-up and reduction is comparable to what is seen from bag house filtration from TwoStage gasifiers. Inspections of the filter showed that a substantial amount of particles were attached to the filter material. However, the particles were easy to remove and the result was again comparable to that of bag filters from a TwoStage gasifier<sup>[28]</sup>. The particles collected from the gas filter had no tar odour, and there were no signs of tar condensation on the filter bags or in the filter house. However, the filter bags had a faint grey colour after being cleaned with pressurized air (see Figure 4.18).




Figure 4.16 Measurement of pressure drop across back house filter on September 24<sup>th</sup> 2009




Figure 4.17 Measurement of pressure drop across back house filter on November 18<sup>th</sup> 2009



Figure 4.18 Picture of an unused bag and a bag after the filtration experiments

#### 4.3.3 Partial Oxidation

Tar measurements have been made on producer gas after passing through the POX reactor. The tar sampling was done with a Petersen Column (§4.2.3). In Figure 4.19 results from three different POX operating conditions are reported. The limited number of experiments reported is due to severe problems with the tar sampling. The predominate problem was soot formation occurring during the partial oxidation. Due to the fact that the flow being sucked through the Petersen Column accounts for approximately 60% of the flow through the POX reactor, the soot load on the column was very high. This resulted in blockage of the glass frit and thus a significant increase in pressure drop across the column which made sampling very hard.




Figure 4.19 The POX temperatures during the experiments

The three successful experiments reported here are:

- POX operating temperature 300°C, no oxidation
- POX operating temperature 800°C, with oxidation
- POX operating temperature 800°C, and no oxidation

Figure 4.19 shows the temperature in the POX reactor during the experiments, the numbering refers to Figure 4.8. Even though the temperatures in the partial oxidation reactor were held as close to the desired temperature as possible it was not possible to uphold a constant temperature throughout the reactor. During the experiments it was therefore decided at least to obtain the desired temperature at the outlet of the reactor. As can be seen in Figure 4.20 there is a decrease in concentration of CO and CH<sub>4</sub> for the POX operation at 800°C with oxidation when compared to POX operation at 300°C. This can be in part accounted for by dilution due to nitrogen from the oxidation air, but since the concentration of CO<sub>2</sub> is almost the same as for the two other operating conditions oxidation of CO and CH<sub>4</sub> also contributes. For POX operation at 800°C without oxidation there is apparently an increase in CH<sub>4</sub> concentration from 4% to 5.4% when compared to POX operation at 300°C. This may be due to thermal cracking of primary tar compounds.

Figure 4.21 and Figure 4.22 show the results of the tar analysis from the three experiments. It is apparent that there is significant reduction in both gravimetric and volatile tar when the producer gas is exposed to high temperature (Figure 4.21). When the crude tar is being thermally treated the oxygenated compounds will be converted into simple PAH, this corresponds very well with what the results seen in Figure 4.22. This mechanism of primary tars being reduced and converted in to PAH (poly-cyclic aromatic hydrocarbons) components is the key functionality of the partial oxidation process. Previous, non-published, studies have shown that at partial oxidation temperatures above 900°C phenol and other primary tars are completely converted into low-molecular PAH compounds, primarily naphthalene.




Figure 4.20 Gas composition of producer gas leaving the POX




Figure 4.21 Overall tar content of producer gas leaving the POX reactor




Figure 4.22 PAH-tar content of producer gas leaving the POX reactor

## 5. System assessment

### 5.1 MILENA-OLGA based combined heat & power system

In order to determine the effect of the MILENA gasification temperature on the design of the OLGA, a predesign is made of the OLGA for a 10 MW<sub>th</sub> combined heat and power plant. For such a combined heat and power plant, the design of the OLGA columns is based on obtaining a tar dew point below 10°C, which means an overall efficiency of tar removal of over 99 percent. Specific attention is paid to the removal of phenol to below 2.5 mg/m<sub>n</sub><sup>3</sup> and of naphthalene to below 40 mg/m<sub>n</sub><sup>3</sup>. The light tars phenol or naphthalene have limited influence on the tar dew point, but are not less problematic. Phenol chemically pollutes the bleed water of downstream condensers and aqueous scrubbers, whereas naphthalene is important as it is known to crystallise at the inlet of gas engines causing a high service demand. By setting the removal standard for naphthalene and phenol that high, similar tar components will be removed to even lower concentration levels due to their lower initial concentration in the raw product gas.

For the comparison, three gasification temperatures are chosen, *i.e.* 776, 832 and 882°C. The corresponding concentrations of naphthalene and phenol are taken from the lab scale experiments (§2.1.3) with beech wood as feedstock and olivine as bed material (Table 5.1). At these concentrations it is expected that the OLGA will not require an additional column for the removal of specific polar components and the bulk composition of the gas differs only slightly that this will not influence the design that much.

Table 5.1 *MILENA 10 MW<sub>th</sub> design parameters*

Gasification temperature	776°C	832°C	882°C
Phenol (mg/m <sub>n</sub> <sup>3</sup> dry)	3460	1348	425
Naphthalene (mg/m <sub>n</sub> <sup>3</sup> dry)	3605	6133	6618

For the OLGA design, it is assumed that the inlet temperature is not changed. Hence, the cooling duty in the collector column is the same, and as the gas itself is also hardly different, the collector column will in all cases have the same design dimensions. The design of the absorber and stripper will be different though. This design is always based on a compromise between naphthalene and phenol removal. Naphthalene has a relatively high solubility in the absorber oil, whereas phenol has a low solubility. In order to improve phenol removal from the product gas, hence, more absorber oil is required. However, as all naphthalene co-absorbed has to be stripper from the oil with air and the amount of stripping air available for this relative complicated desorption is limited, an increasing amount of oil applied will result in a decreased efficiency of naphthalene removal. This is illustrated in Figure 5.1, in which the efficiency of phenol and naphthalene removal is presented as a function of the oil flow.

The three curves presented are all based on a fixed height of the absorber and stripper column as determined for the HVC MILENA 10MW<sub>th</sub> CHP project. The operating temperature of 882°C is taken as the base case, at which both the phenol and naphthalene concentrations are below the design values of 2.5 and 40 mg/m<sub>n</sub><sup>3</sup>. Decreasing the gasification temperature does not have an immediate effect on the required column heights, as it is still possible to have a sufficient tar removal by increasing the amount of absorption oil. Lowering the gasification temperature from 882 to 776°C would require approximately 20% additional oil in the absorber loop. This increase of oil flow would mean that the diameter of the absorber and stripper column has to be increased, although this will be limited to less than 5%. Hence, it can be concluded that lowering the gasification temperature in the MILENA has not a large influence on the design of the columns in OLGA, hence the capital costs.




Figure 5.1 MILENA 10 MW<sub>th</sub> tar removal efficiency for different gasification temperatures

When the gasification temperature is decreased further to below 650°C, something that might be necessary to apply feedstock's like straw and grass with low ash melting points, the need for an additional scrubbing column will increase the costs of the OLGA. In general though, the capital costs of the feedstock are more dominant in the production costs of renewable energy than the capital costs of OLGA. The gasifier will then however produce more heat, as the increased amount of carbon not converted into product gas in the pyrolysis zone of the MILENA will be converted into heat in the combustion zone. It will be depending on the specific demand for either electricity or heat, whether or not this will be an economic advantage.

## 5.2 LT-CFB with gas cooling and cleaning

Based on the successful tests of cooling the gas and particle filtration it seems very likely that a robust gas cooling and cleaning system can be implemented for a LT-CFB gasifier.




Figure 5.2 Principal diagram of Low Temperature gasifier with gas cooling and gas filter

The LT-CFB gasifier is primarily designed for the purpose of co-firing difficult biomass and waste at coal fired power plants. For this use gas cleaning in front of the boiler may be limited to just mechanical separation using just hot cyclones. A further medium to large scale LT-CFB based co-firing option is at natural gas and oil fired power plants. Here (typically) the lack of a neutralising stream of coal ash into the boiler as well as insufficient boiler cleaning facilities and also the lack of flue gas filtering calls for cooling and efficiently filtering the LT-CFB gas in front of the boiler. This however seems quite possible based on the gas cleaning result obtained during the present projects.

Also many further possibilities will probably be feasible e.g. if the LT-CFB gas is further chemically reformed into light gasses.

The first mentioned purpose of co-firing at power plants demands for a large scale up to eventually at least 50-100 MW<sub>th</sub> fuel input. This very demanding task has now been initiated by DONG Energy, and the first (i.e. next) step will be a demonstration facility rated 6 MW<sub>th</sub> fuel input at the Danish DONG Energy owned coal fire power plant “Asnæs” blok 2, which is located in Kallundborg at the western coast of Sealand. The necessary economic support from the Danish PSO-program has already been achieved and the 6 MW<sub>th</sub> gasifier is expected to be operational in 2011. DONG Energy has also the intention of commercialising the LT-CFB gasifier on a global basis and has therefore recently acquired DFBT’s rights and know how related to the technology.

Regarding evaporative coolers, different designs can be applied. For smaller plants (below 10 MW<sub>th</sub>) the design used in the ERA-NET Bioenergy project is recommended. This is a compact design: The cooler is below 6 m tall. However for capacities larger than 10 MW<sub>th</sub> the diameter becomes more than 4 m. One shall then consider using a cooling tower design, where the hot gas enters from the top and water is sprayed into the gas from the side. The evaporative cooling principle is especially an advantage if low temperature heat (district heat) is to be generated, as the energy used for cooling the gas is recovered in a condensing flue gas unit.




Figure 5.3 *Compact cooler design for gas coolers below 10 MW<sub>th</sub> (left) and cooling tower design for gas coolers above 10 MW<sub>th</sub> (right)*

### 5.3 Implementation barriers

History shows that the implementation of bioenergy meets many technical and social barriers. Comprehensive overviews of the opportunities and barriers to bioenergy development in Europe and more specifically for SNG production via biomass gasification were carried out within the framework of two Bioenergy NoE projects<sup>[30,31]</sup>.

Early identification of the barriers that can be expected for the specific gasification and gas cleaning chain will help the development and implementation of this chain. When barriers are assessed a practical way of categorising them is to use a main classification of general bioenergy barriers and of specific barriers to gasification and gas cleaning. Within both categories, a further distinction can be made between technical and non-technical barriers. The latter group contains issues like economics, regulatory and legislation, biomass supply and sustainability, as well as social acceptance.



### 5.3.1 General bioenergy barriers

#### 5.3.1.1 Economics

In the area of economics bioenergy is often associated with high capital costs as well as high feedstock costs and high project development costs<sup>[32]</sup>. Costs of raw biomass materials are usually high and hence have the most significant influence on the end product price, even when considering forest and wood residues due to the high costs of harvesting, collection and storage of these biomasses. The feedstock costs might be lower for low temperature gasification, as (in general) cheap fuels with low ash melting points can be applied, though the feedstock costs will still maintain the predominant factor in the end product price.

With regard to capital costs, these are often considered high for new bioenergy technology compared to conventional utilization or fossil based energy technology<sup>[30,31]</sup>. Furthermore, significant financial support is required for the first demonstration of the new technology<sup>[32]</sup>. Often, this support has to be provided in the form of tax and subsidy schedules as introduced by most EU countries. Due to a non-uniform as well as often changing policy bioenergy activities may be favoured differently in various countries, and as such economic barriers can differ significantly over these countries. Closer investigation<sup>[32]</sup> shows however that bioenergy projects can be economically viable for different technologies in many countries in Europe, for example in the form of heat projects in Austria and Sweden, and co-firing in the United Kingdom, Germany and the Netherlands, even in relation to gasification based projects.

#### 5.3.1.2 Social acceptance

In relation to social aspects, lack of public acceptance is the main barrier. Often this is related to waste to energy facilities and based on the negative perceptions of the facilities impact on public health and local environment. The desire to recover materials as much as possible and not to apply waste streams for energy use can however also form some social barriers. In general though, utilisation of clean biomass fuels does not usually raise a negative public resistance if not affecting to landscape protection<sup>[30,31]</sup> or disturbing the general food production ability. The social acceptability of bioenergy was identified as an issue in all geographic locations, but particularly in the United Kingdom and the United States of America<sup>[32]</sup>.

#### 5.3.1.3 Regulatory and legislation

Environmental regulations may be a barrier that can postpone the building decision of new bioenergy plants, in particular when these plants utilise biogenic wastes or combinations of different (inhomogeneous) biomass fuels. The defining of European fuel standards, both for biomass fuels as well as solid recovered fuels from wastes, enhance trading and certification though, and facilitate a wider accepted use of various biomass fuels<sup>[30,31]</sup>.

#### 5.3.1.4 Biomass supply and sustainability

In Europe, the use of biomass and wastes for energy production is presently about 2.9 EJ per year, with the potential in 2050 estimated to be in the range of 9.0 to 13.5 EJ per year. As the European Commission estimates that the measures of the Biomass Action Plan could lead to an increase in biomass use to about 6 EJ in 2010 or soon after<sup>[30,31]</sup>. Thus the biomass resources and potentials for Europe are still very large, in particular when taking into consideration that in addition to the European reserves, biomass import can also be considered. On the basis of the estimates, there are sufficient domestic resources to meet the European targets set for the year 2010, but if more stringent goals are set for bioenergy in the future, it will be challenging to find sufficient resources in Europe and biomass imports from outside Europe will be necessary.

The future biomass potentials though are affected also by demand for food, productivity of forest and energy crops, availability of degraded land, competing land use types, recoverable residues, environmental requirements, markets and incentives, and research and development progress. Actual developments of these factors will determine the future biomass potential and the competitive use of biomass.

Even if the total biomass resources in the European countries are usually assessed to be sufficient and even huge, the economic collection and transportation distances can significantly decrease the actual potential. This may have an important impact on the feasibility of large scale centralised energy use of biomass. Import of biomass to a port with shipping facilities has been seen as a viable option in countries with a shortage of biomass resources like the Netherlands or otherwise favourable national and local conditions for an excess use of bioenergy like Sweden.

Competition of biomass resources may influence the availability of raw material supply to bioenergy applications. The wood industry and pulp and paper industry are the main industrial consumers of wood raw materials, and a competition situation has been foreseen in Europe due to the high targets and expectations on use of renewable energy. The competition for biomass feedstock might be lower for low temperature gasification, as (in general) less wanted fuels with low ash melting points can be applied. Concerning the use of agricultural crops the competition with food production has been the main public discussion issue. Furthermore, the biomass sustainability issue may hamper the development of bioenergy plant. The Directive on Renewable Energy Sources <sup>[33]</sup>, however, gives clear guidelines on sustainability criteria. The greenhouse gas emission saving from the use of biofuels shall be at least 35%, increasing by 2017 to over 50%.

### 5.3.2 Specific barriers to gasification and gas cleaning

Specific barriers to gasification and gas cleaning relate mainly to either the technical feasibility of gasification and gas cleaning or the implementation scale. In order to reduce costs, gasification is often considered on a scale relatively large compared to other bioenergy projects. This is particularly the case when the raw product gas requires significant gas cleaning in order to be applied for CHP purposes (e.g. gas engines or turbines) or even more advanced synthetic applications (e.g. SNG or FT diesel production). As such, issues on implementation scale are in many cases directly related to biomass supply issues as well as economic issues. The latter ones are strengthened by the technical risks.

Experts from the Thermalnet group, however, considered technical barriers to be less significant than non-technical ones <sup>[32]</sup>. This was explained by the fact that many of them were very close to leading edge research and development work, felt that programs were in place that would address any technical issues still remaining and considered these programs to be progressing towards solutions. The one real technical issue that was highlighted though was the importance of reducing NO<sub>x</sub> emissions. Although authors of this report are not claiming NO<sub>x</sub> emissions can be avoided in their concepts, they consider their tar removal technologies as a step in the direction of applying conventional gas purification (e.g. ammonia) downstream the tar removal for compliance with NO<sub>x</sub> emission limits.



## 6. Conclusions and recommendations

Biomass can be gasified using many different technologies ranging from high-temperature processes as high as 1500°C to low-temperature processes as low as 500°C. The so-called low-temperature biomass gasification processes can have the following advantages:

- Suitable for (generally cheap) fuels with low ash melting points;
- High cold gas efficiency due to less heat loss and less energy demand for heating;
- Low tar dew point resulting in less cooling and fouling problems;
- Easier gas cooling and cleaning due to small content of vaporized ash components;
- Less stringent specifications of fuel composition/homogeneity and on fuel feeding;
- Less heat transfer limitations within gasifier enabling operation at elevated pressure.

The main disadvantage of low-temperature gasification is the relatively high tar level in the gas. This is why these processes generally are not considered being suitable for connection to gas engines, gas turbines, fuel cells or catalytic synthesis reactors. Furthermore, the tars in the gas are less stable as lower as the gasification temperature gets. In particular when temperatures decrease below 650°C there is a shift from non-polar to polar – pyrolysis like – tar components. In order to extend the application of low-temperature gasifiers from simple co-firing to also the mentioned applications, tar removal from the product gas is crucial.

The OLGA tar removal technology can be applied for this in its conventional way as long as the gasification temperature is in the area of 750 to 850°C. In combination with an indirect gasifier, the gasification temperature does not even have a significant influence on the actual design of the columns applied within OLGA and tar removal to an extent that the tar dew point is below 10°C can be achieved. Lowering the gasification temperature below 750°C, however, requires some modifications of the OLGA technology related to the:

- Cooling section in order to avoid condensation and ongoing polymerization of tars;
- Oil recovery system in order to keep the viscosity of the oil within certain limits;
- Absorber oil in order to guarantee removal of polar tars for gasification below 650°C.

It is expected that OLGA can remove also the tars from the product gas of a gasifier operated at temperatures below 650° to low enough levels that a gas engine should run (based on tars). For a full design of an OLGA for such a gasifier, it is recommended to perform a complete tar and C<sub>3+</sub> analysis, so that the necessity of (additional) alternative oils like glycerol or a polar tar condensate in OLGA can be determined. Furthermore, a good measurement of the dust content is required in order to be able to adequately design both the cyclone upstream OLGA and the oil recovery system within OLGA.

For dust removal, bag house filters are commonly used in connection with gasifiers where a dust free gas is essential such as gas engines. It is essential that the temperature of the filter is above the tar dew point of the gas. So far bag house filters have only been used on so-called “low tar gasifiers”, however it can be concluded they can also be applied on “high tar gasifiers” as long as the temperature of the bag filter is above the dew point of the tars. If bag filters should be operated at technically or economically too high temperature levels, the OLGA could be applied in which dust can be removed at a temperature below the original tar dew point of the gas.

Cooling of gasification gas is a challenge as dust and tars result in fouling in shell and tube heat exchangers. To overcome such problems so called “evaporative coolers” can be used where the evaporative energy of water is used to cool the gas.



## Abbreviations and definitions

Bar(a)	Absolute pressure level in bar
Bar(g)	Gause pressure level in bar
BFB	Bubbling fluidized bed
BIVKIN	Circulating fluidized bed gasifier
CFB	Circulating fluidized bed
CHP	Combined heat and power
DME	Dimethyl ether
ESP	Electrostatic precipitator
FT	Fischer-Tropsch
GrC	Degrees Celsius
HGF	Hot gas filter
LT-CFB	Low-temperature circulated fluidized bed gasifier
m <sub>n</sub> <sup>3</sup>	Normal cubic meters
m <sub>a</sub> <sup>3</sup>	Actual cubic meters
MILENA	Indirect fluidized bed gasifier
NoE	Network of excellence
OLGA	Oil based gas washer
ORS	Oil recovery system
PAH	Polyaromatic hydrocarbons
PE	Polyethylene
POX	Partial oxidation
PVC	Polyvinyl chloride
RDF	Refuse derived fuel
RME	Rapeseed methyl ester
SNG	Substitute natural gas
SPA	Solid phase adsorption
TBD	To be determined
WOB	Bubbling fluidized bed gasifier



## References

- [1] Mozaffarian, H., Zwart, R.W.R., Boerrigter, H., Deurwaarder, E., and Kersten, S.R.A., “Green gas as SNG (synthetic natural gas); a renewable fuel with conventional quality”, Science in thermal and chemical conversion, Vancouver, Canada, ECN-RX-04-085, 2008, 17 p.
- [2] Van der Meijden, C.M., Veringa, H.J., Van der Drift, A., and Vreugdenhil, B.J., “The 800 kWth allothermal biomass gasifier MILENA”, Presented at 16th European biomass conference & exhibition, Valencia, Spain, ECN-M-08-083, 2008, 6 p.
- [3] Van der Drift, A., Van der Meijden, C.M., and Boerrigter, H., “MILENA gasification technology for high efficient SNG production from biomass”, Presented at 14th European biomass conference & exhibition, Paris, France, ECN-RX-05-183, 2005, 3 p.
- [4] Van der Drift, A., Van der Meijden, C.M., and Strating-Ytsma, S.D., “Higher carbon conversion in CFB biomass gasifiers” (*in Dutch*), ECN, ECN-C-03-053, 2003, 44 p.
- [5] Vreugdenhil, B.J., and Zwart, R.W.R., “Tar formation in pyrolysis and gasification”, ECN-E-08-087, 2009, pp. 324-335
- [6] Thersites: the ECN tar dew point site <http://www.thersites.nl>
- [7] Van Paasen, S.V.B., Cieplik, M.K., and Phokawat, N.P., “Gasification of non-woody biomass – Economic and technical perspectives of chlorine and sulphur removal from product gas”, ECN, ECN-C-06-032, 2006, 54 p.
- [8] Visser, H.J.M., Zwart, R.W.R., Könemann, H.W.J., Bos, A., and Kuipers, J., “RDF-gasification part 1: characterizing the use of RDF as fuel and solving the tar problem by an in-depth laboratory study”, ECN, Presented at the 2nd international symposium on energy from biomass and waste in Venice, 2008
- [9] Stoholm, P., Nielsen, R.G., Richardt, K., Sander, B., Henriksen, U.B., Qvale, E.B., Gurbuz, S., Brix, M., Hansen, M.W., and Wolff, L., “The Low Temperature CFB Gasifier : Latest 50 KW Test Results and New 500 KW Plant”, Presented at Grafica Lito, Florence, Italy, 2004
- [10] Stoholm, P., Nielsen, R.G., Sarbæk, L., Tobiasen, L., Henriksen, U.B., Fock, M.W., Richardt, K., Sander, B., and Wolff, L., “The Low Temperature CFB Gasifier - Further Test Results and Possible Applications”, Presented at: European Biomass Conference, Amsterdam, 2002
- [11] Stoholm, P., Nielsen, R.G., Nygaard, H., Tobiasen, L., Fock, M.W., Richardt, K., and Henriksen, U.B., “Low temperature CFB gasifier conceptual ideas, applications and first test results”, Presented at World Conference and Exhibition on Biomass for Energy and Industry, Seville, Spain, 2000
- [12] Nielsen, R.G., Stoholm, P., Nielsen, M.B., Nørholm, N., Antonsen, S., Sander, B., Krogh, J., Henriksen, U.B., and Qvale, E.B., “The LT-CFB gasifier : First test results from the 500 kW test plant”, Presented at Biomass for energy, industry and climate protection, 14<sup>th</sup> European conference and exhibition, Paris, 2005
- [13] Zwart, R.W.R., Van der Drift, A., Bos, A., Visser, H.J.M., Cieplik, M.K., and Könemann, H.W.J., “Oil-based gas washing – flexible tar removal for high-efficient production of clean heat and power as well as sustainable fuels and chemicals”, Environmental Progress & Sustainable Energy, vol. 28, no. 3, 2009, 12 p.
- [14] Rabou, L.P.L.M., Zwart, R.W.R., Vreugdenhil, B.J., and Bos, A., “Tar in biomass producer gas, the Energy research Centre of the Netherlands (ECN) experience: an enduring challenge”, Energy & Fuels, vol. 23, pp. 6189-6198



- [15] Könemann, H.W.J., "OLGA tar removal technology", Technical information paper, 2009, 30 p.
- [16] Verhoeff, F., Rabou, L.P.L.M., Van Paasen, S.V.B., Emmen, R., Buwalda, R.A., Klein Teeselink, H., "Preparation bioCHP: 1000 hours duration test" (*in Dutch*), ECN, ECN-E-06-044, 2006, 69 p.
- [17] Simell, P., Ståhlberg, P., Kurkela, E., Albrecht, J., Deutsch, S., and Sjöström, K., "Provisional protocol for the sampling and analysis of tar and particulates in the gas from large-scale biomass gasifiers", *Biomass & Bioenergy*, vol. 18, no. 3, 2000, pp. 19-38
- [18] Abu El-Ruba, Z., Bramer, E.A., and Brem, G., "Experimental comparison of biomass chars with other catalysts for tar reduction", *Fuel*, vol. 87, issues 10-11, 2008, pp. 2243-2252
- [19] Kiel, J.H.A., Van Paasen, S.V.B., Neeft, J.P.A., Devi, L., Ptasinski, K.J., Janssen, F.J.J.G., Meijer, R., Berends, R.H., Temmink, H.M.G., Brem, G., Padban, N., and Bramer, E.A., "Primary measures to reduce tar formation in fluidized-bed biomass gasifiers", ECN, ECN-C-04-014, 2004, 108 p.
- [20] Graham, R.G., and Bergougnou, M.A., "Fast pyrolysis of biomass", *Journal of Analytical and Applied Catalysis*, vol. 6, 1984, pp. 93-135
- [21] Lievens, C., Yperman, J., Cornelissen, T., and Carleer, R., "Study of the potential valorisation of heavy metal contaminated biomass via phytoremediation by fast pyrolysis – Part II: Characterisation of the liquid and gaseous fraction as function of the temperature", *Fuel*, vol. 87, 2008, pp. 1906-1916
- [22] Bos, A., Zwart, R.W.R., "Method and system for gasifying biomass", ECN, Dutch patent application 2003547, September 25th 2009
- [23] 3M<sup>TM</sup> documentation [http://www.3m.com/market/industrial/ceramics/materials/filter\\_product.html](http://www.3m.com/market/industrial/ceramics/materials/filter_product.html)
- [24] Brandt, P., Larsen, E., Henriksen, U. "High Tar Reduction in a Two-Stage Gasifier". *Energy & Fuels* 2000, 14, p. 816-819.
- [25] Ahrenfeldt, J., Henriksen, U., Jensen, T. K., Gøbel, B., Wiese, L., Kather, A., Egsgaard, H. "Validation of a Continuous Combined Heat and Power (CHP) Operation of a Two-Stage Biomass Gasifier". *Energy & Fuels*, paper id. ef0503616, 2006.
- [26] Brandt, P., Henriksen, U. "Decomposition of tar in pyrolysis gas by partial oxidation and thermal cracking. Part 2". In proceedings of the conference: 10th European Conference and Technology Exhibition: Biomass for Energy and Industry". Würzburg. Germany. 8.11. June 1998. pp. 1616-1618
- [27] Ledesma, E.B., Kalish, M.A., Nelson, P.F., Wornat, M.J., and Mackie, J.C., "Formation and fate of PAH during the pyrolysis and fuel-rich combustion of coal primary tar", *Fuel* 79 (2000), pp. 1801-1814.
- [28] Henriksen, U., Ahrenfeldt, J., Jensen, T.K., Gøbel, B., Bentzen, J. B., Hindsgaul C., and Sørensen, L.H., "The Design, Construction and Operation of a 75 kW Two-Stage Gasifier". *Energy* Vol. 31, Issues 10-11, 2006. pp. 1542-1553.
- [29] Van Paasen, S.V.B., Kiel, J.H.A., Neeft, J.P.A., Knoef, H.A.M., Buffinga, G.J., Zielke, U., Sjöström, K., Brage, C., Hasler, P., Simell, P.A., Suomalainen, M., Dorrington, M.A., and Thomas, L., "Guideline for sampling and analysis of tar and particles in biomass producer gases – final report documenting the guideline, R&D work and dissemination", ECN-C-02-090, ECN, Petten, the Netherlands, 2002.

- [30] Fagnäs, L., Johansson, A., Wilén, C., Sipilä, K., Mäkinen, T., Helynen, S., Daugherty, E., Den Uil, H., Vehlou, J., Kåberger, T., and Rogulska, M., “Bioenergy in Europe – Opportunities and barriers”, VTT Research notes 2352, VTT, Espoo, 2006, 118 p.
- [31] Jungmeier, G., Mäkinen, T., Peck, P., Plepys, A., Pucker, J., Wilén, C., and Zwart, R., “Prospects for the production and use of renewable substitute natural gas from biomass”, NoE Bioenergy JER 2.2 final report, SES6-CT-2003-502788, 2009, 64 p.
- [32] Thornley, P., and Prins, W., “Non-technical barriers”, published in “Thermal biomass conversion”, edited by Bridgwater, A.V., Hofbauer, H., and Van Loo, S., CPL Press, 2009, pp. 323-353
- [33] European Parliament, “Promotion of the use of energy from renewable sources”, European Parliament legislative resolution P6\_TA-PROV(2008)0609, 2008, 76 p.